



Deposited via The University of Leeds.

White Rose Research Online URL for this paper:

<https://eprints.whiterose.ac.uk/id/eprint/157096/>

Version: Accepted Version

Article:

Pournaras, E and Espejo-Urbe, J (2017) Self-Repairable Smart Grids Via Online Coordination of Smart Transformers. IEEE Transactions on Industrial Informatics, 13 (4). pp. 1783-1793. ISSN: 1551-3203

<https://doi.org/10.1109/tii.2016.2625041>

© 2016, IEEE. This is an author produced version of a paper published in IEEE Transactions on Industrial Informatics. Uploaded in accordance with the publisher's self-archiving policy.

Reuse

Items deposited in White Rose Research Online are protected by copyright, with all rights reserved unless indicated otherwise. They may be downloaded and/or printed for private study, or other acts as permitted by national copyright laws. The publisher or other rights holders may allow further reproduction and re-use of the full text version. This is indicated by the licence information on the White Rose Research Online record for the item.

Takedown

If you consider content in White Rose Research Online to be in breach of UK law, please notify us by emailing eprints@whiterose.ac.uk including the URL of the record and the reason for the withdrawal request.

Self-repairable Smart Grids via Online Coordination of Smart Transformers

Evangelos Pournaras and Jose Espejo-Urbe

Abstract—The introduction of active devices in Smart Grids, such as smart transformers, powered by intelligent software and networking capabilities, brings paramount opportunities for online automated control and regulation. However, online mitigation of disruptive events such as cascading failures, is challenging. Local intelligence by itself cannot tackle such complex collective phenomena with domino effects. Collective intelligence coordinating rapid mitigation actions is required. This paper introduces analytical results from which two optimization strategies for self-repairable Smart Grids are derived. These strategies build a coordination mechanism for smart transformers that runs in three healing modes and performs collective decision-making of the phase angles in the lines of a transmission system to improve reliability under disruptive events, i.e. line failures causing cascading failures. Experimental evaluation using self-repairability envelopes in different case networks, AC power flows and varying number of smart transformers confirms that the higher the number of smart transformers participating in the coordination, the higher the reliability and the capability of a network to self-repair.

Index Terms—smart transformer, optimization, coordination, cascading failure, reliability, repairable network, self-repairability envelope

I. INTRODUCTION

THE introduction of Information and Communication Technologies (ICT) in traditional power systems has brought phenomenal opportunities for online automated control and decentralized self-regulation in Smart Grids. These new capabilities can increase the integration of renewable energy resources, reduce the operational costs and improve the reliability of power systems under highly disruptive complex phenomena such as cascading failures. Several electrical devices [1], [2] powered by intelligent software play a key role in this new era, e.g. smart transformers [3]. In 2011, smart transformer was chosen by MIT as one of the ten emerging technology breakthroughs that can have the greatest impact in the world [4]. However, a smart transformer by itself cannot shape the future self-repairable Smart Grids. Online coordination of all system components is required to prevent or rapidly respond to disruptive events such as cascading failures and cyber-attacks. This paper contributes a method for online coordination of multiple smart transformers so that their synergistic control of power flow prevents a cascading failure or minimizes its impact when it occurs.

This paper studies the reliability of highly meshed transmission systems with phase shift transformers. Multiple transformers provide redundancy as in case of a single transformer failure, operational flexibility is guaranteed by the remaining ones. The phase angle of the transformers governs the overall power flow distribution in the network and is usually determined via day-ahead operational planning based on forecasts. Decision-making is usually performed offline by system operators [5]. Manual online adjustments can be performed involving coordination with telephone conversations of up to 15 minutes duration [6]. However, the penetration of renewable energy resources, the exchange of flow between regions or even the highly dynamic demand originated from demand-response programs [7] and micro-generation capabilities require an almost real-time and fully automated regulation of phase shift transformers. Regulating the flow of a transmission system with multiple phase shift transformers is challenging as coordination is required given the non-linear dynamics of AC power flow networks. However, the cost-benefits of using coordinating phase shift transformers are well documented in earlier work [8]. As a cascading failure involves several network components, coordinating phase shift transformers is highly applicable in this context and scenarios.

This paper introduces a model of self-repairable Smart Grids using smart transformers. In this paper, a self-repairable Smart Grid refers to the inner system capability to prevent or mitigate failures, such as cascading ones, in an online and automated way using its own cyber-physical assets such as smart transformers. A smart transformer here is defined by a phase shift transformer running software that controls the phase angle and can remotely communicate with other assets of the network running such a software. The proposed model brings together three capabilities when a disruptive event, such as a line failure, occurs: (i) load shedding, (ii) generation balancing and (iii) optimization of flow distribution via coordination of smart transformers. Three healing modes of smart transformers are evaluated in which smart transformers operate at different stages of a cascading failure. This paper contributes analytical expressions that determine the flow in the power lines as a function of the phase angles in the smart transformers. Coordination of the smart transformers is achieved with two optimization strategies evaluated in various reference networks and loading profiles. Results show that the two strategies improve the system reliability by decreasing the load shedded and the lines trimmed. The coordination mechanism can increase the reliability further if more smart transformers participate in the online coordination process.

The main contributions of this paper are summarized as

Manuscript received Month Date, Year; revised Month Date, 2016.

Copyright © 2016 IEEE. Personal use of this material is permitted. However, permission to use this material for any other purposes must be obtained from the IEEE by sending a request to pubs-permissions@ieee.org

Evangelos Pournaras and Jose Espejo-Urbe are with the Professorship of Computational Social Science, ETH Zurich, Zurich, Switzerland. E-mail: {epournaras,josee}@ethz.ch

follows:

- The use case of smart transformers for mitigating cascading failures.
- A coordination algorithm of smart transformers operating in three healing modes against cascading failures that minimizes load-shedding and bounds generation limits.
- Analytical expressions for both AC and DC flow models for the regulation of flows using smart transformers.
- The envelopes of self-repairability. They are introduced as an evaluation methodology to assess the overall resilience of a power network against cascading failures using smart transformers .

This paper is outlined as follows: Section II illustrates a model for self-repairable Smart Grids using two strategies and three healing modes of smart transformers. Section III illustrates analytical expressions for the coordination of smart transformers. It also introduces two optimization strategies that improve the reparability of Smart Grids under N-1 contingency analysis. Section IV evaluates the proposed coordination approach in different networks, AC power flows and varying number of smart transformers. Section V compares the proposed model of self-repairable Smart Grids with related work. Finally, Section VI concludes this paper and outlines future work.

II. SELF-REPAIRABLE SMART GRIDS

This section introduces a model for online repairable Smart Grids under perturbations that influence the flow of the power lines. Such perturbations may include failure of power lines and/or changes of power load and generation. The goal of the model is to mitigate such disruptive events by minimizing their impact until the system returns to its stable state via, for example, manual offline system repair and maintenance. The model can be used for operational planning, as well as real-time mitigation if computational resources are acquired for this purpose. It is applicable to power transmission networks, though the computational optimization methods employed in this paper are relevant for the reliability of power distribution networks as well [9]. Figure 1 shows a high-level illustration of the proposed model for self-repairable Smart Grids.




Fig. 1. A model for self-repairable Smart Grids using coordinating smart transformers.

The model can be realized as a control system shaped over event detection and islanding management. The model requires

the detection of an event that disturbs the balance of supply and demand, e.g. the failure of a power line. Moreover, in case the event disconnects the network resulting in multiple islands, the control system is applied to each formed island.

The sensing part of the model includes the computation of the DC or AC flow in the power lines given (i) the physical characteristics of the network, (ii) constraints in generator limits and (iii) control actions performed by the coordinating smart transformers. Sensing indicates if the system configuration converges, meaning a solution is found that balances supply and demand.

The control part includes the algorithmic logic for actuation given information about the DC/AC power flow. It also concerns the coordination of smart transformers by collectively choosing the phase angles of several phase shift transformers to mitigate flow imbalances. Coordination is performed using two optimization strategies derived from analytical results. They are referred to as STRATEGY 1 and STRATEGY 2. Section III illustrates the analytical results and the strategies in detail.

The actuation part concerns (i) load shedding, (ii) generation balancing, (iii) phase angle shifting and (iv) line trimming. Load shedding reduces the level of the loads in the network given the computations performed in the control part. Load shedding also indicates whether there is a blackout by using the maximum number of iterations or the continuation power flow threshold as possible criteria. Generation balancing sets the operation of slack buses within the range of their minimum and maximum capacity. These physical constraints are usually not determined in the power flow analysis. The coordinated shift of the phase angles is computed in the control part and applied in the actuation part. Finally, line trimming disconnects overloaded power lines to prevent their physical damage.

Algorithm 1 illustrates the healing operations performed for improving the Smart Grid reliability. The algorithm is illustrated for AC power flow. It can be simplified and adjusted for DC power flow as well, given that flow convergence can always be satisfied. Load shedding is a mitigation countermeasure applied when flow does not converge (lines 18-24 in Algorithm 1). There is no universal standardized load reduction strategy among different systems regulators, e.g. ENTOSE-3, NERC, etc. Some possible load-shedding algorithms are outlined in earlier work [10]. Generation limits are met (lines 9-14 in Algorithm 1) by repeating the following process: when the flow of an existing slack buses surpasses its limits, the flow is set to its maximum, if flow is positive, or minimum, if flow is negative. The process repeats by selecting another generator with the highest maximum power suggesting high inertia¹.

A system that mitigates a disruptive event with load-shedding and generation balancing is referred to as BASE CASE, in contrast to STRATEGY 1 and STRATEGY 2 that additionally employ coordinating smart transformers. Smart transformers can operate in three *healing modes* under AC flows: (i) HEALER 1 mitigates a cascading failure right after a system perturbation and before load shedding is applied (core stage). HEALER 1

¹The inertia of a generator is proportional to its nominal power (maximum power) [11]. In real operation, the saturation of the power output, meaning in this case the generation limits, is given by primary and secondary frequency control contracts [12].

Algorithm 1 Event mitigation with smart transformers.

Require: detection of disruptive events

```

1: Early stage: run smart transformer coordination
2: for each disruptive event do
3:   extract islands
4:   for each island do
5:     while line limits are violated do
6:       loop
7:         flow = power flow analysis
8:         if flow is converged then
9:           if limits are not violated then
10:            return
11:          else
12:            meet generator limits
13:            flow = power flow analysis
14:          end if
15:          if load is not shedded then
16:            Core stage: run smart transformer coordination
17:          end if
18:          else if flow is not converged and is not blackout then
19:            for iteration 1 to maximum do
20:              load = shedded
21:              flow = power flow analysis
22:              if flow is converged then
23:                return
24:              end if
25:            end for
26:            if iteration = maximum then
27:              flow = blackout
28:            end if
29:            else if flow is blackout then
30:              return
31:            end if
32:          end loop
33:          Final stage: run smart transformer coordination
34:        end while
35:      end for
36:    end for
    
```

aims at system recovery before it falls into severe disturbances by load shedding actions. HEALER 1 does not require major interventions in the current load shedding actions of system operators. (ii) HEALER 2 combines HEALER 1 with "zero-cost" preventive actions undertaken by smart transformers before perturbations (early and core stage), as motivated in earlier work [8], [13]. (iii) HEALER 3 mitigates cascading failures after a system perturbation and after load shedding is applied (final stage). This scenario is studied for the shake of completeness and comparisons of the proposed model. It has an exploratory role. For the case of DC flows, HEALER 1 and HEALER 3 are equivalent as DC does not have power convergence issues.

The proposed model can be used for operational planning, reliability post-analysis and online regulation of power flow. The latter scenario requires communication infrastructure and computational resources to meet an almost real-time control. Such opportunities are addressed in related work [14], [15], [16], [17]. The smart operation and coordination of smart transformers are illustrated in the following section.

III. COORDINATION OF SMART TRANSFORMERS

This section studies the coordination of phase shift transformers in a transmission network of N buses and L links with DC or AC power flow. The mathematical symbols used for the rest of this paper are outlined in Table I in the order they appear. The topology of the network is represented by the incidence matrix C of a directed graph. Coordination is achieved via optimization of the active power flow $\mathbf{f} = [f_1, f_2, f_L]^T$ in the network by adjusting the angles φ of the phase shift

transformers. Therefore, optimization requires calculation of the power flow in each line as a function $\mathbf{f}(\varphi)$ of the phase shift angle in each transformer. For this reason, the rest of this section provides analytical expressions formulated in matrices that can be used in several optimization strategies. Two such strategies are illustrated in this section.

TABLE I
AN OVERVIEW OF THE MATHEMATICAL SYMBOLS

Symbol	Interpretation
N	Number of buses
L	Number of lines
C	Incidence matrix of a directed network
\mathbf{f}	Vector of active power flow in lines
f_ℓ	The active power flow over a line ℓ
φ	Vector of phase shift angles
H_{angle}	Matrix of sensitivity factors for the shifts of angles
\tilde{B}_{line}	Line susceptance matrix, no reference & slack buses
\tilde{B}_{bus}	Bus susceptance matrix, no reference & slack buses
I	Identity matrix
\mathbf{b}	Vector of the series susceptance in lines
$\mathbf{1}^T$	Transposed vector of 1s
b_ℓ	The series susceptance of line ℓ
x_ℓ^s	The series reactance of line ℓ
B_{line}	Line susceptance matrix
B_{bus}	Bus susceptance matrix
$\Delta \mathbf{f}$	Vector of power flow transfers over a line ℓ
$\Delta \mathbf{p}$	Vector of power flow transfers between buses
$\Delta \varphi$	Vector of shifts in phase angles
H_{bus}	Matrix of sensitivity factors for bus power transfers
H_{line}	Matrix of sensitivity factors for line power transfers
\mathbf{f}^0	Vector of initial power flow in lines
φ	Vector of phase shift angles in lines
φ_ℓ	Phase shift angle of line ℓ
φ_0	Vector of initial phase shift angles in lines
g_ℓ	Vector of phase shift distribution factor for line ℓ
G_{angle}	Matrix of phase shift distribution factors in DC
k	Number of smart transformers in a network
λ	Penalty parameter over control action
$\Delta \varphi_\ell$	The shift of the phase angle in line ℓ
$\Delta \varphi_{max}$	A maximum permitted shift of the angle in line ℓ
φ_{max}	A maximum value of the phase shift angle
$a_{i,\ell}$	1 0 element of line ℓ exceeding a threshold
\mathbf{a}_i	Vector of 1 0 line elements exceeding a threshold
β_i	Threshold i used in STRATEGY 2
v	Number of thresholds used in STRATEGY 2
w_i	Weight of vector \mathbf{a}_i
L_p	Load shedded
\hat{p}	Final load
p	Initial load
L_l	Trimmed lines
\hat{L}	Final number of non-trimmed lines
L	Initial number of non-trimmed lines
U	Lines utilization
r_ℓ	The rating of line ℓ

Theorem 1 provides the sensitivity factors for the phase shift angles of the power lines required to measure the power flow in the lines as a function of the angles. By using smart phase shift transformers to perform an actual control of the phase shift angles, the power flow in the lines can be optimized. This paper studies whether this flow optimization results in higher resilience under disruptive events such as cascading failures.

Theorem 1. *The matrix of sensitivity factors for the phase shift angles in a transmission network with DC or AC power flow is given as follows:*

$$\mathbf{H}_{angle} = (\mathbf{C} \cdot (\tilde{\mathbf{B}}_{line} \cdot \tilde{\mathbf{B}}_{bus}^{-1})^T - \mathbf{I})(\mathbf{b} \cdot \mathbf{1}^T), \quad (1)$$

where \mathbf{C} is the incidence matrix representing the transmission network as a directed graph, $\tilde{\mathbf{B}}_{line}$, $\tilde{\mathbf{B}}_{bus}$ is the line and bus susceptance matrices excluding the reference and slack buses,

I is the identity matrix and $\mathbf{b} = [b_1, b_2, \dots, b_L]^T$ is the vector of the series susceptance in the lines.

Proof. Given the vector $\mathbf{b} = [b_1, b_2, \dots, b_L]^T$ of the series susceptance in the lines, where each element involves the series reactance as $b_\ell = \frac{1}{x_s^\ell}$, the line susceptance matrix can be expressed as follows:

$$\mathbf{B}_{line} = (\mathbf{b} \cdot \mathbf{1}^T) \mathbf{C}. \quad (2)$$

The bus susceptance matrix can be similarly derived as follows:

$$\mathbf{B}_{bus} = \mathbf{C}^T \mathbf{B}_{line}. \quad (3)$$

If the reference and slack bus columns are excluded, the bus and line susceptance matrices are referred to as $\tilde{\mathbf{B}}_{bus}$ and $\tilde{\mathbf{B}}_{line}$ respectively. The matrix of sensitivity factors for the power flow transfers $\Delta \mathbf{p}$ between buses is defined as follows:

$$\mathbf{H}_{bus} = \frac{\Delta \mathbf{f}}{\Delta \mathbf{p}} = \tilde{\mathbf{B}}_{line} \cdot \tilde{\mathbf{B}}_{bus}^{-1}. \quad (4)$$

Similarly, the matrix of the sensitivity factors for the shift $\Delta \varphi$ of phase angles can be expressed as follows:

$$\mathbf{H}_{angle} = \frac{\Delta \mathbf{f}}{\Delta \varphi} = \mathbf{H}_{line} (\mathbf{b} \cdot \mathbf{1}^T). \quad (5)$$

Given that the matrix of the sensitivity factors for the power flow transfers between lines is given by $\mathbf{H}_{line} = (\mathbf{C} \cdot \mathbf{H}_{bus}^T - \mathbf{I})$, it is derived that:

$$\mathbf{H}_{angle} = (\mathbf{C} \cdot (\tilde{\mathbf{B}}_{line} \cdot \tilde{\mathbf{B}}_{bus}^{-1})^T - \mathbf{I}) (\mathbf{b} \cdot \mathbf{1}^T). \quad (6)$$

□

Given the initial power flow, and the matrix of sensitivity factors for the phase shift angles determined in Theorem 1, the power flow of lines after shifts in phase angles is derived in Corollary 1.

Corollary 1. *The DC or AC power flow $\mathbf{f} = [f_1, f_2, f_L]^T$ of L lines in a transmission network with phase angles $\varphi = [\varphi_1, \varphi_2, \dots, \varphi_L]^T$ is computed as follows:*

$$\mathbf{f}(\varphi) = \mathbf{f}^0 + \mathbf{H}_{angle} \Delta \varphi, \quad (7)$$

where \mathbf{f}^0 is the vector of the initial DC or AC power flow in the lines, \mathbf{H}_{angle} is the matrix of sensitivity factors for the phase angles and $\Delta \varphi$ is the vector of shifts in the phase angles of the lines.

Proof. The power flow f_ℓ in a line ℓ can be written as a function of the phase angles in lines using a Taylor series expansion:

$$f_\ell(\varphi) = \sum_{n=0}^{\infty} \frac{\partial^{(n)} f_\ell}{\partial \varphi^n} \Big|_{\varphi=\varphi_0} \Delta \varphi^n, \quad (8)$$

where the vector of phase angles $\varphi = \varphi_0 + \Delta \varphi$ is given by the vector of the initial phase angles φ_0 and the vector with the shifts of the phase angles $\Delta \varphi$. The series can be approximated in its first two terms as follows:

$$f_\ell(\varphi) \approx f_\ell(\varphi_0) + \mathbf{g}_\ell \Delta \varphi, \quad (9)$$

where $f_\ell(\varphi_0)$ is the vector of power flow in the lines given the initial angles of the lines. The \mathbf{g}_ℓ is a phase shift distribution factor and is represented by the vector of the derivatives for the power flow of line ℓ with respect to the vector of angles φ in the lines. It is computed as follows:

$$\mathbf{g}_\ell = \frac{\partial f_\ell}{\partial \varphi} \Big|_{\varphi=\varphi_0}. \quad (10)$$

For a vector formulation, Equation 9 can be written as follows:

$$\mathbf{f}(\varphi) = \mathbf{f}^0 + \mathbf{G}_{angle} \Delta \varphi, \quad (11)$$

given (i) the matrix approximation of the phase shift distribution factors $\mathbf{G}_{angle} \approx \frac{\Delta \mathbf{f}}{\Delta \varphi}$ for a DC formulation in Δ changes, (ii) the vector of flows $\mathbf{f} = [f_1, f_2, f_L]^T$ and (iii) $\mathbf{f}(\varphi_0) = \mathbf{f}^0$. However, from Theorem 1, Equation 5, it holds that:

$$\frac{\Delta \mathbf{f}}{\Delta \varphi} = \mathbf{H}_{angle} \approx \mathbf{G}_{angle}, \quad (12)$$

therefore it is proven that:

$$\mathbf{f}(\varphi) = \mathbf{f}^0 + \mathbf{H}_{angle} \Delta \varphi. \quad (13)$$

□

Given Theorem 1 and Corollary 1, the smart operation and coordination of phase shift transformers can be turned into a computational optimization problem for determining the phase angles of lines equipped with smart transformers. This section formulates two optimization strategies of power flow that assume a subset of $k \leq L$ lines equipped with phase shift transformers for influencing the phase angle. The transformers influence the phase angle of the line locally, however the flow distribution of the whole network may be influenced after such an action. The optimization strategies influence this flow redistribution such that a cascading failure is mitigated.

Strategy 1. *The DC or AC power flow \mathbf{f} of L lines in a transmission network can be optimized by minimizing the 2-norm as follows:*

$$\begin{aligned} & \min \|\mathbf{f}\|_2 + \lambda \|\Delta \varphi\|_2 \\ & \text{subject to} \quad \mathbf{f} = \mathbf{f}^0 + \mathbf{H}_{angle} \Delta \varphi \\ & \quad |\Delta \varphi_\ell| \leq \Delta \varphi_{max}, \forall \ell \in 1, \dots, k \\ & \quad |\varphi_\ell| \leq \varphi_{max}, \forall \ell \in 1, \dots, k \end{aligned} \quad (14)$$

where \mathbf{f} is given by Corollary 1, λ is the penalty parameter over the control action, $\Delta \varphi_\ell$ is the shift of the phase angle in line ℓ , φ_ℓ is the phase shift angle of line ℓ , $\Delta \varphi_{max}$ is the maximum shift of phase angles and φ_{max} is the maximum value the phase shift angles can have.

The bounds of the angles and phase angle shifts can be chosen empirically by evaluating the power flow convergence. The magnitude of angle adjustments is regulated by the penalty parameter λ applied over the control action. A version of STRATEGY 1 is used in earlier work [18], in contrast to STRATEGY 2 that is introduced here and is formulated as follows:

Strategy 2. The DC or AC power flow \mathbf{f} of L lines in a transmission network can be optimized by minimizing the product of weighted power flows as follows:

$$\begin{aligned} \min \quad & \sum_{i=1}^v \sum_{j=1}^L w_i a_{i,\ell} + \lambda \|\Delta\varphi\|_2 \\ \text{subject to} \quad & \mathbf{f} = \mathbf{f}^0 + \mathbf{H}_{angle} \Delta\varphi \\ & |\Delta\varphi_\ell| \leq \Delta\varphi_{max}, \forall \ell \in 1, \dots, k \\ & |\varphi_\ell| \leq \varphi_{max}, \forall \ell \in 1, \dots, k \\ & a_{i,\ell} = \begin{cases} 1 & \text{if } |f_\ell| \geq \beta_i \\ 0 & \text{otherwise} \end{cases} \\ & \forall \ell \in 1, \dots, L \\ & \forall i \in 1, \dots, v \end{aligned} \quad (15)$$

where \mathbf{f} is given by Corollary 1, λ is the penalty parameter over the control action, $\Delta\varphi_\ell$ is the shift of the phase angle in line ℓ , φ_ℓ is the phase shift angle of line ℓ , $\Delta\varphi_{max}$ is the maximum shift of phase angles, φ_{max} is the maximum value the phase shift angles can have, $a_{i,\ell}$ is the 1 or 0 element of line ℓ from the vector \mathbf{a}_i that indicates if the power flow f_ℓ exceeds a threshold β_i and w_i is the weight of the vector \mathbf{a}_i .

The rest of this paper evaluates how the reliability of a Smart Grid against cascading failures can be improved by optimizing the power flow with the two optimization strategies.

IV. EVALUATION

This section illustrates the experimental evaluation of the coordination mechanism for smart transformers. The system is implemented in Matlab and makes use of the MATPOWER library². The Mosek³ solver is used for the optimization. Three case networks⁴ are evaluated: (i) case-30, with 4 smart transformers, (ii) case-39 with 5 smart transformers and (iii) case-29⁵ with 6 smart transformers. Due to space restrictions, results are obtained for the AC power flow analysis models that is more challenging to study and relevant for all healer modes. These case networks are chosen as they contain capacity information, the line ratings, for each line that makes the optimization with smart transformers more realistic and challenging compared to only using the tolerance parameter. The line ratings vary in case-30 to show the influence of line capacities on system reliability. Moreover, the number of transformers varies from 2 to 15 in some of the experiments to show whether more transformers result in higher reliability.

The overall system reliability of a specific case network equipped with smart transformers is evaluated under an N-1 contingency analysis with three relative metrics: (i) *load shedded* L_p , (ii) *lines trimmed* L_l and (iii) *lines utilization* U .

²Available at <http://www.pserc.cornell.edu/matpower/> (last accessed: July 2016)

³Available at <https://www.mosek.com> (last accessed: October 2016)

⁴Case-30 and case-39 are standard IEEE benchmark networks [19] and case-29 is a representative model of electricity transmission network in Great Britain: Available at <http://www.maths.ed.ac.uk/optenergy/NetworkData/reducedGB/> (last accessed: July 2016).

⁵This network is used as follows: An initial power flow analysis detects trimmed lines. The line rating of these lines is doubled and optimal power flow is performed to derive the BASE CASE.

Measurements are performed at every change in the status of the network, e.g. when each line fails during a cascading failure. The load shedded is measured as follows:

$$L_p = 1 - \frac{\hat{p}}{p} \quad (16)$$

where \hat{p} and p are the final and initial load served in the N-1 contingency analysis. The lines trimmed are measured as follows:

$$L_l = 1 - \frac{\hat{L}}{L} \quad (17)$$

where \hat{L} and L are the initial and final number of non-trimmed lines in the N-1 contingency analysis. The lines utilization is measured as follows:

$$U = \frac{1}{L} \sum_{\ell=1}^L \frac{f_\ell}{r_\ell}, \quad (18)$$

when f_ℓ is the flow of line ℓ and r_ℓ is the line rating of line ℓ representing the line capacity.

As the positioning of the transformers is not the focus of this paper, the experiments are repeated for 10 random placements of the smart transformers. Particularly, the random placement for the case-30 takes places at the lines that do not connect the generators and affect the flow. Load shedding is performed by applying a 5% proportional reduction of the load in the respective nodes for every iteration required for convergence [20]. A maximum number of 15 iterations are executed for convergence. The settings of the optimization strategies are chosen empirically as follows: (i) $\lambda = 0$, $\Delta\varphi_{max} = 16^\circ$, $\varphi_{max} = 7^\circ$ for STRATEGY 1 and STRATEGY 2. (ii) $\beta_1 = 0.6, w_1 = 1, \beta_2 = 0.8, w_2 = 10$ and $\beta_3 = 0.95, w_3 = 100$ for STRATEGY 2. In lines with transformers it holds that $w_3 = 1000$. When the penalty parameter is used in the experiments $\lambda > 0$, then $\lambda = 0.1$ for STRATEGY 1 and $\lambda = 1.0$ for STRATEGY 2. These number are chosen after applying a random search of the optimization space in the range $\lambda \in [0, 20]$ in increments of 0.1. Figure 1 in Supplementary Information⁶ shows an example of this process.

Results are illustrated by binning in 100 bins the values of the performance metrics derived from each line removal in the N-1 failure scenarios and computing the cumulative distribution function. The cumulative distribution functions⁷ of the 10 random placements of the smart transformers form the *envelope of self-repairability* of a given network. Table I, II and III in Supplementary Information⁶ provide illustrative examples of how the cumulative distribution functions are computed for each performance metric. The raw values for case-29 are illustrated in a table given that not all lines

⁶Available at <http://evangelospourmaras.com/wordpress/wp-content/uploads/2016/10/SI-Self-repairable-Smart-Grids-via-Online-Coordination-of-Smart-Transformers.pdf> (last accessed: October 2016)

⁷A cumulative distribution function provides an aggregate picture of the results under the N-1 contingency analysis and the different placements of smart transformers. For a given metric in the x-axis, a cumulative distribution function shifted to the left indicates low overall values of this metric, whereas, a cumulative distribution function shifted to right indicates high overall values of this metric.

can be equipped with smart transformers. The goal of the experimental evaluation is to compare the system reliability of STRATEGY 1 and STRATEGY 2 and make a contrast to the BASE CASE under (i) different healing modes, (ii) different networks and (iv) varied number/placements of transformers.

A. Load shedding

Figure 2 shows the envelopes of self-repairability for case-39. STRATEGY 2 has the lowest load shedded in all healer modes, with HEALER 2 having the minimal one. The penalty parameters make the strategies more stable without significantly lowering the load-shedding.




Fig. 2. Load shedded in case-39 with AC power flow under different healing modes and λ values for STRATEGY 1 and STRATEGY 2 respectively.

With the default low load level of case-30, no significant load shedding is observed. If case-30 is stretched by decreasing the rating of the lines by 50% as shown in Figure 3, significant load shedding is performed that is much higher compare to the case-39. STRATEGY 2 has the lowest overall load shedded and the most stable performance given the lower area size of the envelope. The load shedded in minimal for HEALER 2.

Table II shows the load shedded values in case-29. It can be observed that certain line removals, e.g. lines 15 and 16, have a catastrophic effect for BASE CASE and STRATEGY 1 in all healer modes, whereas, STRATEGY 2 successfully mitigates the cascading failure. Given that the values of the tables indicate to a high extent the trimmed lines and lines utilization, the case-29 is omitted from the results for the rest of this section.




Fig. 3. Load shedded in case-30 with AC power flow under different healing modes and λ values for STRATEGY 1 and STRATEGY 2 respectively.

TABLE II
LOAD SHEDDING (%) AFTER EACH LINE REMOVAL IN CASE-29 WITH AC POWER FLOW. DIFFERENT HEALING MODES ARE EVALUATED EACH WITH STRATEGY 1 AND STRATEGY 2.

Line Removal	1	3	5	6	15	16	18	23	24
BASE CASE	0.9	0.9	0.9	0.9	100	100	0.9	100	100
STRATEGY 1	0.9	0.9	0.9	0.9	100	100	0.9	100	100
STRATEGY 2	0.9	0.9	0.9	0	0	0	0	100	100
STRATEGY 1	0.9	0.9	0	0	100	100	0.9	100	100
STRATEGY 2	0.9	0.9	0.9	0	0	0	0.9	9.5	9.5
STRATEGY 1	0.9	0.9	0.9	0.9	100	100	0.9	100	100
STRATEGY 2	0.9	0.9	0.9	0	0	0	0	100	100

Healer 1 Healer 2 Healer 3


B. Lines trimmed

Figure 4 illustrates the lines trimmed in case-39. The envelopes confirm the highest mitigation capability of STRATEGY 2 and HEALER 2. The penalty parameter has a low negative effect.


Figure 5 illustrates the lines trimmed in the performed experiments with case-30. It is also confirmed here that case-39 is a more robust network against cascading failures compared to case-30 with the chosen settings. HEALER 2 has on average high, but varied, performance as indicated by the size of the envelope area.

C. Lines utilization


Figure 6 illustrates the lines utilization in case-39. HEALER 3 has the lowest lines utilization because of the highest damage the network experiences as illustrated earlier. In contrast, for a higher but highly balanced utilization of the lines, HEALER 2 justifies its highest resilience.




(a) HEALER 1, $\lambda = 0, 0$



(b) HEALER 2, $\lambda = 0, 0$




(c) HEALER 3, $\lambda = 0, 0$




(d) HEALER 2, $\lambda = 0.1, 1.0$


Fig. 4. Lines trimmed in case-39 with AC power flow under different healing modes and λ values for STRATEGY 1 and STRATEGY 2 respectively.




(a) HEALER 1, $\lambda = 0, 0$



(b) HEALER 2, $\lambda = 0, 0$




(c) HEALER 3, $\lambda = 0, 0$




(d) HEALER 2, $\lambda = 0.1, 1.0$


Fig. 6. Lines utilization in case-39 with AC power flow under different healing modes and λ values for STRATEGY 1 and STRATEGY 2 respectively.




(a) HEALER 1, $\lambda = 0, 0$



(b) HEALER 2, $\lambda = 0, 0$



(c) HEALER 3, $\lambda = 0, 0$



(d) HEALER 2, $\lambda = 0.1, 1.0$

Fig. 5. Lines trimmed in case-30 with AC power flow under different healing modes and λ values for STRATEGY 1 and STRATEGY 2 respectively.

In contrast to case-39, case-30 has broader envelopes due to higher instability of the network as shown in Figure 7. The envelope of STRATEGY 2 is broader but highly shifted to the right compared to the envelope of STRATEGY 1.

D. Number and positioning of transformers

Figure 8a illustrates the load shedded in case-39 under varying number of smart transformers using HEALER 3. It shows that a higher number of smart transformers results in a more effective optimization of the power flow for both strategies. The superiority of STRATEGY 2 over STRATEGY 1 is confirmed here as well with an 4.9% lower average load shedded.

Figure 8b illustrates the lines trimmed in case-39 under varying number of smart transformers. It is confirmed here as well that a higher number of smart transformers result in higher reliability. STRATEGY 2 shows on average 2% lower number of lines trimmed compared to STRATEGY 1.

Table III and IV illustrates the 10 random placements of smart transformers and the load shedded performed in case-30 and case-39 respectively. The smart transformers positions can be analyzed using topological and graph spectra metrics to design meta-heuristics for robust smart transformer placements. Such an analysis is out of the scope of this paper and it is part of future work.

E. Computational aspects

The proposed coordination scheme for smart transformers can be used by system operators to precompute mitigation




Fig. 7. Lines utilization in case-30 with AC power flow under different healing modes and λ values for STRATEGY 1 and STRATEGY 2 respectively.




Fig. 8. Load shedded and lines trimmed in case-39 and HEALER 3 with AC power flow and varying number of smart transformers.

actions. This may involve running the optimization in the control centers with frequent historic scenarios of failures. Devices such as phase measurement units (PMUs) can make data accessible to control centers in real-time [21], [22] so that the mitigation actions are immediately triggered. PMUs may provide data with the rate of up to 60 [23] or even 120 samples⁸ per seconds in some industrial solutions. The feasibility of this approach is also shown in earlier work via the design of backup strategies under predefined systems conditions, The backup strategies use real-time fault analysis such as event

⁸Available at <http://www.alstom.com/press-centre/2014/8/alstom-and-pge-to-advance-synchrophasor-grid-monitoring-into-proactive-grid-stability-management/> (last accessed: October 2016)

TABLE III
LOAD SHEDDING (%) FOR EACH SMART TRANSFORMER PLACEMENT IN CASE-30.

BASE CASE	Position	STRATEGY 1			STRATEGY 2		
		50.5					
1	34 37 5 35 24	47.3	54.9	49.2	46.2	45.6	46.1
2	4 12 22 37 36	48.6	47.7	46.3	43.1	48.4	43.1
3	7 39 38 19 30	47.3	68.8	51.8	59.8	47.1	59.8
4	6 17 36 31 39	47.7	47.7	49.2	45.7	51.2	45.7
5	27 2 34 36 26	47.8	41.5	46.3	47.2	52.1	48.2
6	32 30 16 25 7	73.3	67.5	74.4	48.3	49.1	48.3
7	29 2 11 40 4	48.0	42.8	47.8	46.3	52.4	46.3
8	34 28 13 37 2	48.5	45.6	46.1	45.4	45.3	45.4
9	18 16 30 31 7	71.9	50.4	72.1	48.2	49.1	48.2
10	21 18 26 27 28	48.5	42.5	49.4	52.4	46.8	52.4

Healer 1 Healer 2 Healer 3

TABLE IV
LOAD SHEDDING (%) FOR EACH SMART TRANSFORMER PLACEMENT IN CASE-39.

BASE CASE	Position	STRATEGY 1			STRATEGY 2		
		16.4					
1	36 40 7 38 25	16.8	16.8	17.2	13.6	13.6	14.4
2	6 12 24 40 38	12.3	9.2	13.3	8.4	1.9	8.5
3	8 44 42 21 30	15.2	15.2	16.1	7.8	6.8	8.0
4	7 19 40 31 38	14.2	14.2	14.5	12.1	12.2	11.9
5	28 3 36 38 27	12.8	12.8	12.7	9.9	8.4	10.0
6	32 31 16 26 8	10.7	8.7	10.7	5.4	0.8	5.4
7	30 3 12 44 6	12.2	12.2	12.9	0.8	0.8	0.8
8	36 29 13 40 3	13.1	10.5	13.0	3.3	5.0	3.3
9	21 16 31 43 8	11.5	9.4	11.5	6.5	0.8	6.6
10	23 21 27 28 29	15.8	15.8	15.7	15.9	16.1	18.0

Healer 1 Healer 2 Healer 3

trees [24] or controlled and optimized islanding of a power system in the order of milliseconds for its protection [25].

Given that cascading failures may be triggered by highly unexpected events, the computational cost for an entirely online optimization is evaluated in Figure 9. The two mitigation strategies are evaluated with HEALER 2, $\lambda = 0$ in three power networks. The benchmark runs in a Dell inspiron n5110 personal computer with 6GB memory, Intel(R) Core(TM) i7-2630QM CPU @ 2.00GHz with Ubuntu 15.10. The N-1 contingency analysis runs in parallel and the results show the average execution time of a single link removal. Two processing overheads are measured: (i) the optimization time that includes the underlined operations in Algorithm 1 and (ii) the other operations time that includes the rest of the operations shown in Algorithm 1.

Figure 9 confirms that the computational operations can be rapidly performed with a time overhead of a few seconds. Processing completes in less than 4 seconds in all cases. The time of the other operations is limited to a few milliseconds approaching a real-time operation. The time overhead can be further decreased by running the proposed system on a larger computer infrastructure than a personal computer. Although case-39 is the largest network, it has the lowest total time overhead as it is the most robust one against cascading failures as confirmed by the self-repairability envelopes.

Earlier work identifies slow and medium cascades that evolve in the order of minutes and seconds [26], [27]. The results confirm that the proposed scheme for self-repairable smart grids using smart transformers is highly applicable for




Fig. 9. Computational times for STRATEGY 1 and STRATEGY 2 under HEALER 2 with $\lambda = 0$ for three power networks.

these cascades as parallel computations can be performed in milliseconds or in a few seconds even in a personal computer. Accessing larger and more expensive Big Data infrastructures available in control centers would be the way to deal with the larger networks that require a longer optimization. Moreover, both the optimization algorithms and the power flow calculations involve at a lower level several matrix operations that can be parallelized over GPUs with tremendous performance enhancements as studied in earlier work [28], [29].

V. COMPARISON WITH RELATED WORK

Related work on smart transformers mainly focuses on frequency control [30], voltage stability [31], [32], [33], [34], demand-response in distribution networks with multiple feeders [35] or integration on medium and low voltage microgrids [36], [37], [38]. In most of this work, a single on-load tap-changer transformer [39] is considered. In other work in which coordination of multiple transformers is considered among the transmission system operators of different countries [5], no automation and online operation is performed, e.g. optimization of allocation markets with power transformers. Moreover in the related work of [13], the corrective coordinated actions of phase shift transformers implicitly assume controllability of the overloaded lines. It is unclear how this proposed method can be applied in cascading failure scenarios that may involve load shedding or redispatch of generation.

An analytical approach to grid operation with phase shift transformers is earlier studied [18]. In contrast, this paper builds upon an analytical model and provides four contributions: (i) coordination and optimization can be performed in both AC and DC flow models. (ii) Analytical expressions formulated in matrices with all system components. (iii) Limited ranges for the phase angles are taken into account. (iv) System reliability is stretched by disruptive events that result in cascading failures. In contrast to STRATEGY 1 proposed in this paper that balances the overall utilization of the lines, this related work sets line utilization to a precomputed distribution. Monitoring is restricted to the interconnectors instead of all other influenced lines. Finally, the scope of this related methodology is mainly the optimization of border capacity between different

areas. This work expands to cascading failure scenarios. In addition, post-fault precomputed corrective actions by smart transformers in case-29 are earlier introduced [8]. In contrast to this work, no automated response or an overall coordination among smart transformers is performed.

A meaningful quantitative comparison of this work with other related approaches is challenging. The reliability or reparability of power networks with smart transformers, under disturbances potentially leading to cascading failures, is usually not systematically studied. For example, a distributed multi-agent coordination of smart transformer control is introduced earlier [6]. Agents controlling physical assets of power grids communicate in real-time and control the phase angle of smart transformers. Although this approach is very promising and indicates future opportunities for distributed coordination of smart transformers, the evaluation methodology is limited to assessing individual lines that are overloaded. However, given the non-linear dynamics of AC power systems, an overall system-wide assessment is required. Decreasing the load in one line with smart transformers may result in even higher load in other lines that are usually well-balanced. The cumulative distribution functions in the evaluation methodology of Section IV show this effect. Therefore, evaluating the cost-effectiveness of any coordination mechanisms for smart transformers requires the overall assessment of the flow distribution in the network. This work exactly fills this gap.

VI. CONCLUSION AND FUTURE WORK

This paper concludes that coordinating smart transformers can provide a higher reliability in Smart Grids under disruptive events such as cascading failures or cyber-attacks. This is shown by analytically deriving two optimization strategies with which load shedded and lines trimmed are decreased while lines utilization becomes more balanced under N-1 contingency analysis. A higher number of smart transformers participating in the coordination process improves further reliability as shown with the envelopes of self-reparability in the performed experimental results.

The model proposed for self-repairable Smart Grids is extensible as other optimization strategies can be further tested as well. For example, an optimization strategy for regulating voltage stability is part of future work. Moreover an expression of the phase shift distribution factors in AC would make the model more accurate. Finally, fully decentralized sensing mechanisms studied in earlier work [40] could make the proposed model computationally scalable to large-scale network with all components interacting and self-regulating power flow in a collective fashion.

ACKNOWLEDGMENT

This research is funded by the Professorship of Computational Social Science, ETH Zurich, Zurich, Switzerland. The authors would like to thank Ben-Elías Brandt, Manish Thapa and the rest of the SFINA project team for their comments and support on this research.

REFERENCES

- [1] J. Shea, "Understanding facts-concepts and technology of flexible ac transmission systems [book review]," *Electrical Insulation Magazine, IEEE*, vol. 18, no. 1, pp. 46–46, Jan 2002.
- [2] E. Pournaras, M. Yao, R. Ambrosio, and M. Warnier, "Organizational control reconfigurations for a robust smart power grid," in *Internet of Things and Inter-cooperative Computational Technologies for Collective Intelligence*. Springer, 2013, pp. 189–206.
- [3] M. Liserre, G. Buticchi, M. Andresen, G. D. Carne, L. F. Costa, and Z. X. Zou, "The smart transformer: Impact on the electric grid and technology challenges," *IEEE Industrial Electronics Magazine*, vol. 10, no. 2, pp. 46–58, Summer 2016.
- [4] D. H. Freedman, "Smart transformers-controlling the flow of electricity to stabilize the grid," MIT Technology Review, 10 Emerging Technologies Breakthroughs, pp. 44–45, May 2011.
- [5] O. Arrivé, F. Boulet, C. Moran-Pena, P. Johnson, J. Van Roost, N. Schuster, O. Ziermann, H. Ziesemann, M. Heinz, M. Pierchalla *et al.*, "Improved tso coordination in the central west european region," in *Cigre Session 2012 Conf*, 2012.
- [6] S. Muller, U. Hager, and C. Rehtanz, "A multiagent system for adaptive power flow control in electrical transmission systems," *Industrial Informatics, IEEE Transactions on*, vol. 10, no. 4, pp. 2290–2299, Nov 2014.
- [7] E. Pournaras, M. Vasirani, R. E. Kooij, and K. Aberer, "Decentralized planning of energy demand for the management of robustness and discomfort," *Industrial Informatics, IEEE Transactions on*, vol. 10, no. 4, pp. 2280–2289, 2014.
- [8] M. Belivanis and K. R. Bell, "Coordination of phase-shifting transformers to improve transmission network utilisation," in *2010 IEEE PES Innovative Smart Grid Technologies Conference Europe (ISGT Europe)*. IEEE, 2010, pp. 1–6.
- [9] R. Pena-Alzola, G. Gohil, L. Mathe, M. Liserre, and F. Blaabjerg, "Review of modular power converters solutions for smart transformer in distribution system," in *Energy Conversion Congress and Exposition (ECCE), 2013 IEEE*, Sept 2013, pp. 380–387.
- [10] S. Pahwa, C. Scoglio, S. Das, and N. Schulz, "Load-shedding strategies for preventing cascading failures in power grid," *Electric Power Components and Systems*, vol. 41, no. 9, pp. 879–895, 2013.
- [11] "Frequency stability evaluation criteria for the synchronous zone of continental europe," ENTSOE, Tech. Rep. RG-CE System Protection & Dynamics Sub Group, March 2016.
- [12] G. Andersson, "Dynamics and control of electric power systems," EEH-Power Systems Laboratory, ETH Zurich, February 2012, lecture 227-0528-00, ITET ETH.
- [13] A. Marinakis, M. Glavic, and T. Van Cutsem, "Minimal reduction of unscheduled flows for security restoration: application to phase shifter control," *IEEE Transactions on Power Systems*, vol. 25, no. 1, pp. 506–515, 2010.
- [14] P. Kansal and A. Bose, "Bandwidth and latency requirements for smart transmission grid applications," *Smart Grid, IEEE Transactions on*, vol. 3, no. 3, pp. 1344–1352, Sept 2012.
- [15] M. Grötschel, S. O. Krumke, and J. Rambau, *Online optimization of large scale systems*. Springer Science & Business Media, 2013.
- [16] J. Zhan, N. Stoimenov, J. Ouyang, L. Thiele, V. Narayanan, and Y. Xie, "Designing energy-efficient noc for real-time embedded systems through slack optimization," in *Proceedings of the 50th Annual Design Automation Conference*, ser. DAC '13. New York, NY, USA: ACM, 2013, pp. 37:1–37:6.
- [17] A. Gehm, J. Quevedo, M. da Silva Martins, and R. Beltrame, "A low-cost gprs based communication system for a smart transformer," in *Industry Applications (INDUSCON), 2014 11th IEEE/IAS International Conference on*, Dec 2014, pp. 1–6.
- [18] J. Verboomen, D. Van Hertem, P. H. Schavemaker, W. L. Kling, and R. Belmans, "Analytical approach to grid operation with phase shifting transformers," *Power Systems, IEEE Transactions on*, vol. 23, no. 1, pp. 41–46, 2008.
- [19] R. D. Zimmerman, C. E. Murillo-Sánchez, and R. J. Thomas, "Matpower: Steady-state operations, planning, and analysis tools for power systems research and education," *IEEE Transactions on power systems*, vol. 26, no. 1, pp. 12–19, 2011.
- [20] D. P. Nedic, I. Dobson, D. S. Kirschen, B. A. Carreras, and V. E. Lynch, "Criticality in a cascading failure blackout model," *International Journal of Electrical Power & Energy Systems*, vol. 28, no. 9, pp. 627–633, 2006.
- [21] I. Kaitovic, S. Lukovic, and M. Malek, "Proactive failure management in smart grids for improved resilience: A methodology for failure prediction and mitigation," in *2015 IEEE Globecom Workshops (GC Wkshps)*, Dec 2015, pp. 1–6.
- [22] S. Savulescu, *Real-time stability in power systems: techniques for early detection of the risk of blackout*. Springer, 2014.
- [23] J. Giri, "Proactive management of the future grid," *IEEE Power and Energy Technology Systems Journal*, vol. 2, no. 2, pp. 43–52, 2015.
- [24] N. Zhang and M. Kezunovic, "Improving real-time fault analysis and validating relay operations to prevent or mitigate cascading blackouts," in *2005/2006 IEEE/PES Transmission and Distribution Conference and Exhibition*. IEEE, 2006, pp. 847–852.
- [25] S. Koch, S. Chatzivasileiadis, M. Vrakopoulou, and G. Andersson, "Mitigation of cascading failures by real-time controlled islanding and graceful load shedding," in *Bulk Power System Dynamics and Control (iREP)-VIII (iREP), 2010 iREP Symposium*. IEEE, 2010, pp. 1–19.
- [26] D. Bienstock, G. Grebla, and G. Zussman, "Optimal control of cascading power grid failures with imperfect flow observations," in *SIAM Workshop on Network Science (NS14)*, 2014, pp. 1–2.
- [27] J. Song, E. Cotilla-Sanchez, G. Ghanavati, and P. D. Hines, "Dynamic modeling of cascading failure in power systems," *IEEE Transactions on Power Systems*, vol. 31, no. 3, pp. 2085–2095, 2016.
- [28] K. Balasubramaniam, G. K. Venayagamoorthy, and N. Watson, "Cellular neural network based situational awareness system for power grids," in *Neural Networks (IJCNN), The 2013 International Joint Conference on*, Aug 2013, pp. 1–8.
- [29] Z. Qin, "Construction of generic and adaptive restoration strategies," *HKU Theses Online (HKUTO)*, 2015.
- [30] G. D. Carne, G. Buticchi, M. Liserre, and C. Vournas, "Frequency-based overload control of smart transformers," in *PowerTech, 2015 IEEE Eindhoven*, June 2015, pp. 1–5.
- [31] G. D. Carne, M. Liserre, K. Christakou, and M. Paolone, "Integrated voltage control and line congestion management in active distribution networks by means of smart transformers," in *2014 IEEE 23rd International Symposium on Industrial Electronics (ISIE)*, June 2014, pp. 2613–2619.
- [32] G. D. Carne, G. Buticchi, M. Liserre, C. Yoon, and F. Blaabjerg, "Voltage and current balancing in low and medium voltage grid by means of smart transformer," in *2015 IEEE Power Energy Society General Meeting*, July 2015, pp. 1–5.
- [33] J. Quevedo, J. Giacomini, R. Beltrame, F. Cazakevicius, C. Rech, L. Schuch, T. Marchesan, M. de Campos, P. Sausen, and J. Kinan, "Smart distribution transformer applied to smart grids," in *Power Electronics Conference (COBEP), 2013 Brazilian*, Oct 2013, pp. 1046–1053.
- [34] J. C. Kester, P. J. Heskes, J. Kaandorp, J. Cobben, G. Schoonenberg, D. Malyna, E. C. de Jong, B. J. Wargers, and A. Dalmeijer, "A smart mv/lv-station that improves power quality, reliability and substation load profile," in *Electricity Distribution - Part 1, 2009. CIRED 2009. 20th International Conference and Exhibition on*, June 2009, pp. 1–4.
- [35] W. Khamphanchai, M. Kuzlu, and M. Pipattanasomporn, "A smart distribution transformer management with multi-agent technologies," in *Innovative Smart Grid Technologies (ISGT), 2013 IEEE PES*, Feb 2013, pp. 1–6.
- [36] T. Vandoorn, J. De Koning, B. Meersman, J. Guerrero, and L. Van-develde, "Voltage-based control of a smart transformer in a microgrid," *Industrial Electronics, IEEE Transactions on*, vol. 60, no. 4, pp. 1291–1305, April 2013.
- [37] P. Kadurek, J. Cobben, and W. Kling, "Smart mv/lv transformer for future grids," in *Power Electronics Electrical Drives Automation and Motion (SPEEDAM), 2010 International Symposium on*, June 2010, pp. 1700–1705.
- [38] P. Kadurek, J. Cobben, and W. L. Kling, "Smart transformer for mitigation of voltage fluctuations in mv networks," in *10th International Conference on Environment and Electrical Engineering (E3EIC)*, May 2011, pp. 1–4.
- [39] P. Bauer and S. de Haan, "Electronic tap changer for 500 kva/10 kv distribution transformers: design, experimental results and impact in distribution networks," in *Industry Applications Conference, 1998. Thirty-Third IAS Annual Meeting. The 1998 IEEE*, vol. 2, Oct 1998, pp. 1530–1537 vol.2.
- [40] E. Pournaras, M. Warnier, and F. M. Brazier, "A generic and adaptive aggregation service for large-scale decentralized networks," *Complex Adaptive Systems Modeling*, vol. 1, no. 1, p. 19, 2013.