



Deposited via The University of Sheffield.

White Rose Research Online URL for this paper:

<https://eprints.whiterose.ac.uk/id/eprint/169664/>

Version: Published Version

Article:

Alshehri, F., Beck, S., Ingham, D. et al. (2021) Technico-economic modelling of ground and air source heat pumps in a hot and dry climate. Proceedings of the Institution of Mechanical Engineers, Part A: Journal of Power and Energy, 235 (5). pp. 1225-1239.
ISSN: 0957-6509

<https://doi.org/10.1177/0957650920976051>

Reuse

This article is distributed under the terms of the Creative Commons Attribution (CC BY) licence. This licence allows you to distribute, remix, tweak, and build upon the work, even commercially, as long as you credit the authors for the original work. More information and the full terms of the licence here:

<https://creativecommons.org/licenses/>

Takedown

If you consider content in White Rose Research Online to be in breach of UK law, please notify us by emailing eprints@whiterose.ac.uk including the URL of the record and the reason for the withdrawal request.

Technico-economic modelling of ground and air source heat pumps in a hot and dry climate

Faisal Alshehri , Stephen Beck, Derek Ingham, Lin Ma and Mohammed Pourkashanian

Proc IMechE Part A:
J Power and Energy
0(0) 1–15
© IMechE 2020



Article reuse guidelines:
sagepub.com/journals-permissions
DOI: 10.1177/0957650920976051
journals.sagepub.com/home/pia



Abstract

In a hot and dry country such as Saudi Arabia, air-conditioning systems consume seventy per cent of the electrical energy. In order to reduce this demand, conventional air-conditioning technology should be replaced by more efficient renewable energy systems. These should be compared to the current standard systems which use air source heat pumps (ASHPs). These have a poor performance when the air temperature is high. In Saudi Arabia, this can be as much as 50 °C. The purpose of this work, therefore, is to simulate and evaluate the performance of ground source heat pumps (GSHPs) compared with systems employing (ASHPs). For the first time, both systems were comprehensively modelled and simulated using the Transient System Simulation (TRNSYS). In addition, the Ground Loop Design (GLD) software was used to design the length of the ground loop heat exchanger. In order to assess this configuration, an evaluation of a model of a single story office building, based on the climatic conditions and geological characteristics that occur in the city of Riyadh in Saudi Arabia was investigated. The period of evaluation was twenty years in order to determine the Coefficient of Performance (COP), Energy Efficiency Ratio (EER) and power consumption. The simulation results show that the GSHP system has a high performance when compared to ASHP. The average annual COP and EER were 4.1 and 15.5 for the GSHP compared to 3.8 and 11 for the ASHP respectively, and the GSHP is a feasible alternative to ASHP with an 11 years payback period with an 18% total cost saving over the simulation period and 36% lower annual energy consumption. The TRNSYS model shows that despite the positive results of the modeling, the high rate of the underground thermal imbalance (88%) could lead to a system failure in the long term

Keywords

Ground source heat pump, air source heat pump, hot/dry climates

Date received: 12 June 2020; accepted: 19 October 2020

Introduction

Nowadays the use of renewal energy has become a fundamental choice in most developed and developing countries, in order to reduce the energy demand and CO₂ equivalent emissions. In hot/dry and hot/humid climate countries such as in the Middle East and North Africa (MENA), most of the energy consumption is used for heating and cooling purposes. In Saudi Arabia for example, a building's HVAC system will consume seventy per cent of the electrical energy provided for each building, a situation that has therefore demanded that alternative ways must be found to eliminate this waste of energy, thereby minimizing the electricity demand and CO₂ emissions.

Over time, air source heat pumps (ASHP) have become the most popular and commonly used systems for cooling and heating. These use outside air for both climate seasons, one for the heat source and

the other for the heat sink.¹ External temperature variations can cause a drop in performance in either season if, for example, the summers are too hot or the winters too cold.

On the other hand, GSHPs are considered the most efficient HVAC technology^{2,3} because the underground temperature remains almost constant all year-round. This means that the effect of the ambient temperature is limited and the difference in temperature between what is considered desirable (inside

Energy 2050, Department of Mechanical Engineering, Faculty of Engineering, University of Sheffield, Sheffield, UK

Corresponding author:

Faisal Alshehri, Energy 2050, Department of Mechanical Engineering, Faculty of Engineering, University of Sheffield, Sheffield S3 7RD, UK.
Email: falshehri1@sheffield.ac.uk

the building) and the surrounding medium (underground soil) is small compared to the outside temperature. This is due to the fact that the underground temperature relates favourably to the annual average air temperature, particularly at ten metres in depth where it remains almost constant.

However, despite GSHPs being well established in cold regions worldwide, their use remains limited in hot and dry regions, such as in the MENA countries. Unfortunately, very few studies are available concerning the use of geothermal heat pumps in hot climate regions.

A study of the energy performance of horizontal ground source heat pumps in cooling mode, used in northern Tunisia, has been carried out by Nabiha et al.⁴ As part of this work, two factors were defined in order to investigate the system performance based on both heat rejection and extraction from the ground. This experimental study showed that, when used in Tunisia in this way, the coefficient of performance (COP) for the GSHP was high and it was therefore shown to be one of the best solutions for reducing electrical energy in the building sector.

An experimental study into the thermal performance of an Earth-Air Heat Exchanger (EAHE) system was used in Egypt by Serageldin et al.⁵ and experimental data was employed to validate the simulations using the ANSYS Fluent and MATLAB codes. In that study, investigations were carried out into five parameters for the pipes that were used and these were diameter, length, spacing, materials used and fluid flow velocity. The following results emerged:

- Increases in pipe diameter caused a decrease in outlet air temperature.
- Increases in fluid velocity caused a gradual decrease in outlet air temperature.

For ground source heat pumps to be used with confidence in hot/dry climates, certain critical design factors have to be achieved. If the underground heat exchanger (in this case an earth—air exchanger (EAHE)), can reduce the temperature of the incoming air to that of the surrounding soil at the selected depth, then the temperature difference between the ambient outside air in the hottest months and the air being returned will be suitable to allow a GSHP to be used.

An example of an earth—air exchanger was investigated by Belatrache et al.⁶ using climatic conditions of the Algerian Sahara and a horizontal earth—air heat exchanger. The experiment used a 45metre length of buried PVC pipe at a depth of 5 metres. The test showed that the air-flow rate of the exchanger reduced the incoming air temperature from 46°C to 25°C (soil temperature). This indicated that it would be possible to use a GSHP in these conditions.

A representative experimental investigation was carried out to assess energy savings on a comparative basis between GSHP's and ASHP's, has been performed in Arizona, US. The data emerged as a result of an initial feasibility study⁷ into the use of a GSHP system for a small office building in the capital, Phoenix. The objective was to present a detailed evaluation of the energy performance and technical feasibility of both a vertical and horizontal closed loop system. The results showed that a 40% saving in energy could be achieved by using the GSHP, compared to the ASHP. However, an important variable emerged as a result as to whether the soil was saturated or dry. If the soil was saturated, the life of the heat exchanger would be shortened by about one quarter. In terms of payback times, the horizontal loop achieved 2.3–4.7 years, but the vertical system could take as long as 25 years.

In contrast, in a harsh cold climate where there is a high demand for heating, such as Canada and the Scandinavia countries, GSHP has proven its ability to produce highly efficient results. For example, Healy and Ugursal⁸ compare the economic feasibility between GSHP and three conventional heating systems, including (electric resistance heat, oil-fired furnace and ASHP) for a residential house in Nova Scotia, Canada where the required heating load was 22,800 kWh compared to 2,300 kWh for cooling. The study illustrated that the GSHP system is the most economic system for the fifteen-year life period.

In moderate Mediterranean climate zones, such as Cyprus, Paul et al.⁹ investigated the feasibility of using GSHPs compared to ASHP based on experimental data and a CFD model. The study showed that the long payback period of the GSHP and the nowadays high efficiency of ASHP systems reduced the chances for the economic success of GSHP.

The first GSHP system was installed in Palestine in the city of Ramallah - Mediterranean climate zones - with a 23 kW cooling/heating capacity and 10 boreholes with 70 m depth.¹⁰ This pilot project achieved a COP of 4.2 in heating and 14.5 EER in cooling. However, it is important to note that the main design conditions for this project were the outside temperature in the summertime, which was 31 °C, and the soil temperature was 18.3 °C. This project proved the feasibility of the GSHP system, which reduces the operating costs by 67% compared to conventional boilers for heating and air-source split units for cooling, and the payback period was 4.2 years.

Likewise, in Jordan, the American University of Madaba has installed a large GSHP system with an approximate capacity of 1.7 MW and 1.4 MW for cooling and heating, respectively, and it serves an educational building.¹¹ 422 boreholes of depth 100 m were connected to 26 heat pumps units to meet the building demand for the cooling and heating where the operation hours are from 7 am to 5 pm for approximately 330 days per year. The results show

that the University saved 2,00,000 kWh electricity and 100,000 litres of diesel fuel per year. The system COP were 6 and 4.5 for the heating and cooling, respectively.

To use GSHP in many countries needs more data about weather and geological zones. For example, in China, Zhihua et al.¹² investigated the feasibility of using GSHP in an office building in five different climate zones based on the COP value. The e-QUEST and TRNSYS were employed in this study, and the results show that in the very cold and cold cities the GSHP is applicable. In contrast, in the hot and warm cities, such as Guangzhou, the GSHP system is not feasible due to the thermal imbalance between the cooling and heating seasons.

The published comparative data on the use of GSHPs in Saudi Arabia, which could be regarded as comprehensive, is virtually non-existent. In the previous paper by the authors¹³ the visibility of using GSHPs in a hot and dry climate was investigated. A techno-economic analysis approach was applied to compare the economics of GSHP to ASHP. The ASHRAE method was applied to design the GHX length and the payback period, cost energy saving, and the thermal imbalance wear analyzed. The result of this paper shows that despite the length of the payback period (approx. 16 years), the GSHP system is worthy of further investigation.

The acceptability of a new system depends on its efficiency and cost-effectiveness. The purpose of this paper, for the first time, is to increase the accuracy by analysing the behavior, performance and technical feasibility of a GSHP compared to the equivalent ASHP in a very harsh hot climate, such as Saudi Arabia. The industry standard modelling tool¹⁴ TRNSYS was used to develop and model both systems under the climate and geological characteristics of the city of Riyadh in Saudi Arabia. This has resulted in the performance of the GSHP achieving a very high COP with a long-term analysis. Thus, GSHP can be beneficially employed in hot dry regions throughout the world.

System simulation using TRNSYS

The software package known as Transient Systems Simulation (TRNSYS) was originally developed at the University of Wisconsin and has been commercially available since 1975, following which it has now become a point of reference on a global scale for researchers, designers and engineers.¹⁴

The software has been, and still is, primarily used in the fields of renewable energy engineering and building simulations and its main advantage is that it has a modular structure that gives the programme enormous flexibility. This flexibility enables the modeling of a variety of energy systems to different levels of complexity where users are able to describe the system components and the manner in which they

are connected. TRNSYS consists of several programmes (TRNSYS Simulation Studio, TRNSYS3d, TRNFLOW, TRNLizard and TRNBuild for multi-zone buildings). The software meets the requirements of the European Standard for solar thermal systems ENV-12977-2 and the building model included in the software, known as 'Type 56', complies with the requirements of ANSI/ASHRAE 140-2001, the American Standard Method of Test for the Evaluation of Building Energy Computer Programmes and, the Building Energy Simulation Test (BESTEST). In addition, it meets the requirements of the European Directive on the Energy Performance of Buildings.^{14,15}

Building envelope model

In this study, an exemplar building has been selected for the comparison. The design of the building envelope represents a typical house or small commercial building in a city. As shown in Figure 1, a single storey office building has been considered for the purposes of this simulation. With the simplifications that have been introduced, the model is not intended to be architecturally realistic, but this does not affect the general results.

Despite the building envelope being outside the scope of this research, the scientific approach used here is a general one, which other users could apply to real designs. In this case, the selection of envelope elements would lead to accurate energy predictions and would also be a useful guide to select the most appropriate size for an HVAC system. Therefore, in most cases, the building's envelope and orientation would have a significant impact on the simulation results.

The total building surface area is about 120 m², the height is 3 m with a gross volume of 360 m³. There are windows on three sides of the building and the fourth side has a main door. There are no sun shading devices and the sun affects all sides of the building. This means that the cooling loads will be much higher than normal.

TRNSYS (TRNSYS3d and TRNBuild) were used to simulate the thermal performance of this building. The main thermal compulsory characteristics of the building envelope, such as being thermally insulated, meant that the U-values for walls, roof and windows were chosen, based on the Saudi Building Code 2018¹⁶ the minimum requirements shown in this code, based on the building location zones (See Figure 2) are set out in Table 1. This model will be used in comparison to both systems. Despite the lower the U-value being the best, the wall, roof, windows and door U-value were defined as 0.24, 0.20, 2.80 and 2.60 W/m² K, respectively.




Figure 1. (a) Schematic of the single-story office building investigated. (b) Walls construction details.




Figure 2. Saudi Arabia Climate Zones based on Saudi Building Code.¹⁶

Building load estimation

Saudi Arabia is a large country with different climate zones and different geological characteristics from one region to another. More information about the natural environment of Saudi Arabia can be found in.¹⁷ The capital city of Riyadh has been selected to be the location for this study. The city has a very hot and dry climate in summer with generally mild weather in winter, with little rainfall and low relative humidity.

In order to investigate the energy use, TRNSYS software has been employed to estimate the cooling and heating loads. The size of a heating or cooling system for a building is determined on the basis of the desired indoor conditions that must be maintained, based on the outdoor conditions that exist at that location. Table 2 shows the design conditions for the building, based on the climate in Riyadh and the ASHRAE standard. For example, the building of the ventilation rate use was based on the ANSI/ASHRAE Standard 62.1-2010 (Ventilation for Acceptable Indoor Air Quality).

Table 1. The U-Values for low-rise/residential buildings.¹⁶

Opaque elements (W/m ² K)	Zone 1	Zone 2	Zone 3
Roofs	0.20	0.24	0.27
Walls	0.34	0.4	0.45
Opaque Doors –All Assemblies	2.84	2.84	2.84
Vertical Glazing - 25% of wall			
All Assemblies	2.67	2.67	2.67
Skylight with Curb Glass % of Roof			
0% –3% All Types	4.26	4.26	4.26

Table 2. Design conditions for the building investigated: Summer period.

Outside conditions	44 °C RH 45% - August
Inside conditions	24 °C RH 50%
Area	120m ² with suspended ceiling, 3 m Height
Located	24.4 N
Operation hours	8:00 am to 6:00 pm weekdays.
People	Assumed 12
Equipment	Assumed 12 watt/m ²
Lighting	Assumed 20 watt/m ²
Ventilation/person	Assumed 8.5 l/sec

Based on the design conditions shown in Table 2, the cooling and heating loads were computed by employing TRNSYS for all months, as shown in Table 3 and Figure 3. Based on the local climatic and design conditions, the maximum cooling and heating loads were 14 kW and 10 kW, respectively. It will be seen that the annual equivalent full load hours (AEFLH) were to be 2,552 and 374, respectively.

Heat pump simulation

The main advantage of a heat pump is the ability to transfer more energy than it consumes. In simple terms, the COP and EER describe the performance of the heat pump. The actual COP is the how many times more heat the system provides than it requires work (electricity, generally) to drive. It is a measure of

the heating performance of the heat pump system, which is defined as follows:

$$COP = \frac{Q_{out}}{W_{in}} \quad (1)$$

Where W_{in} is the electricity consumption, Q_{out} is the output of the heating or cooling. The EER generally refers to the cooling device to measure the cooling performance, which is defined as follows:

$$EER = \frac{Q_C}{P_w} \quad (2)$$

Where, Q_C is the output cooling energy (Btu/h) and P_w is the electrical power (W). It is easy to show that the relation between COP and EER can be expressed as follows:

$$EER = COP \times 3.124 \quad (3)$$

Table 3. Estimated cooling and heating loads for building investigated.

M	Cooling load		Heating load	
	kWh	Peak (kW)	kWh	Peak (kW)
Jan	3	1	1,701	10
Feb	96	5	896	7
Mar	789	7	121	4
Apr	2,230	10	1	1
May	4,952	13	0	0
Jun	5,793	14	0	0
Jul	6,587	14	0	0
Aug	6,631	14	0	0
Sep	4,854	12	0	0
Oct	2,916	10	0	0
Nov	606	6	137	4
Dec	27	2	1159	7
	cumulative	max. peak	cumulative	max. peak
	35,484	14	4,014	10

So for the rest of this document, we will only report on COP.

In fact, there are several unconventional ways to increase the efficiency of the heat pump, for example,¹⁸ is one case where the wastewater from the bathroom increases the efficiency of the heat pump in cold climates, where the efficiency increases by 55%. Likewise¹⁹ investigated experimentally and numerically the effect of the implementation of a thermoelectric cooler on the heat pump COP of air-to-water and air-to-air thermoelectric coolers. The results show that a 30–50% higher COP could be achieved from an air-to-water rather than an air-to-air system.

In addition, it is known that the refrigerant type affects the COP of the system. However, the effect of the refrigerant type is beyond the scope of this paper. Therefore, the same coolant R-410a was used for both ASHP and GSHP to avoid any effect on the comparison in the system efficiency. Furthermore, R 410a was used because it is now the most common type used in Saudi Arabia and in the world due to its characteristics, such as environmentally friendly qualities and high cooling capacity.

Air source heat pump

The ASHP system is the traditional system used for refrigeration and air conditioning in residential buildings and small business buildings in Saudi Arabia.

For simulation purposes with this modeling package, an air-to-air heat pump, type 119 was selected and this was the rooftop unit YORK ZE/EN series.²⁰ The data in the manufacturer’s catalogue was used to model the ASHP. The capacity of the pump selected was 10.5 kW and 17.5 kW for the heating and cooling, respectively. While this is higher than the value given in Table 3 it is a safety factor to account for extreme events.

The simulation runs for a full-year period based on the TMY2 (typical meteorological years) data. During the test period, the ambient temperature




Figure 3. Cooling and heating loads for the building created by TRNSYS.




Figure 4. Outside and inside building temperature during the simulation period.




Figure 5. COP for the ASHP unit.

varied from 0 °C to 45 °C. Figure 4 shows the outside temperature and inside set temperature (21 °C in the winter and 24 °C in the summer) when the ASHP was operating and the model time step was 0.02/hour (1 minute, 12 seconds). In addition, Figure 4 shows the operation period for the ASHP in both cooling and heating (heating on and cooling on). It is clear that the cooling remained dominant most of the year with 8 months when there is a large difference between the indoor and outdoor temperature, this is up to 21 °C in the summertime which requires substantial work from the compressor, which adversely affects the performance of the system.

In these regions, the hottest months provide a challenge for ASHP systems as the ambient temperature can reach 50 °C. Thus, we must place a greater emphasis on the hottest months when calculating the COP and EER. Figure 5 shows the COP for the ASHP during the simulation period and Table 4

Table 4. The annual COP and power consumption of the ASHP and GSHP unit.

M	Overall power consumption (kWh)			Overall COP	
	GSHP	ASHP	% Saving	ASHP	GSHP
Jan	362	684	47	4.71	5.32
Feb	170	290	41	4.68	5.32
Mar	148	210	29	4.29	4.21
Apr	686	963	29	3.55	4.03
May	1,379	2,210	38	3.36	3.80
Jun	1,693	2,806	40	3.22	3.59
Jul	2,025	3,271	38	3.15	3.47
Aug	2,116	3,366	37	3.14	3.37
Sep	1,490	2,244	34	3.36	3.42
Oct	797	1,069	25	3.60	3.56
Nov	144	179	20	4.16	3.82
Dec	174	312	44	4.73	5.40
Overall	11,183	17,602	36	3.83	4.11

shows the average monthly COP and power consumption during the simulation period that starts at midnight on 1st January until midnight on the 31st December (8,760 calendar hours).

In this paper, the ASHP unit has been selected and this is similar to the GSHP unit in terms of characteristics and specifications (such as the source of power, refrigeration type, compressor type, unit efficiency and the cooling/heating capacity) in order to make a fair comparison between the two systems.

Ground source heat pump modeling

The GSHP can be seen to be more efficient than the ASHPs and, incidentally, it is also classified as a renewable energy system because GSHP uses the heat from the underground as a source of energy. Generally, GSHPs consists of three main parts: a heat pump, a distribution system and a ground heat exchanger (GHX). Thus, understanding the geology and hydrogeology of the underground soil (ground layer) is an essential element in the design process for a GHX. Additional information on the geothermal conditions in Saudi Arabia can be found in.²¹

For the purposes of this study, two elements must be carefully calculated to obtain the optimum length of the GHX, namely the thermal conductivity and the underground temperature.

Thermal conductivity. For the purposes of this study, variable geological characteristics were obtained from the report prepared for the Ministry of Petroleum and Mineral Resources in Saudi Arabia and the US Geological Survey²² so as to be able to investigate the heat-flow measurements. The soil in Riyadh consists of clay, silt, sand and gravel in different proportions. However, the thermal geological characteristics of the soil^{21,22} can be summarized as follows:

- (i) Average thermal conductivity is 2.6 W/(m K).
- (ii) Thermal diffusivity is $6.252 \times 10^{-6} \text{ m}^2/\text{s}$.
- (iii) Thermal resistance is 0.315 m K/W.

Underground temperature. ASHRAE and many simulation programs, such as TRNSYS, use equation (4), as developed by Kasuda²³ to calculate the underground temperature at different depths.

$$T_{soil(D,year)} = T_{men} - T_{amp} \times \exp\left(-D\sqrt{\frac{\pi}{365*\alpha}}\right) \times \cos\left(\frac{2\pi}{365}\left(t_{year} - t_{shift} - \frac{D}{2}\sqrt{\frac{365}{\pi*\alpha}}\right)\right) \quad (4)$$

where:

$$D = \text{depth below the surface (surface} = 0)$$




Figure 6. Underground temperature for Riyadh city at different depths.

$T_{soil(D,year)}$ = soil temperature at a depth D and time of year,

T_{mean} = mean surface temperature (average air temperature). The temperature of the ground at an infinite depth will be at this temperature

T_{amp} = amplitude of surface temperature ((maximum air temperature - minimum air temperature)/2)

α = thermal diffusivity of the ground (soil)

t_{year} = current time (day)

t_{shift} = day of the year of the minimum surface temperature

Figure 6 shows the underground temperature for Riyadh city at different depths based on the daily weather data collected for Riyadh city, 2018.

Based on equation (4) the underground temperature for Riyadh city at a depth of over 10m is assumed to be 26.5°C. However, in this work, the value of 29°C was used in the TRNSYS simulation, based on the experimental studies²² that have been performed at five different locations in Saudi Arabia. This investigation is therefore a pessimistic scenario.

Sizing of the GHX. Correctly determining the length of the heat exchanger significantly determines the economic feasibility of using GSHP. The initial cost of the geothermal pump related to the cost of

implementing the geothermal heat exchanger and geological studies for the region.

Based on the thermal conductivity and underground temperature as calculated above (2.6 W/m K and 29°C, respectively) two methods have been applied to estimate the size of the GHX as follows:

- (i) ASHREA method.
- (ii) Ground loop design software, GLD.²⁴

Both methods are based on the monthly and peak loads. A single borehole with a diameter of 128 mm and 6 m spacing between pipes was employed and the borehole characteristics and considerations are shown in Table 5.

ASHREA method: The use of the ASHRAE equation to calculate the length of GHX is widely used to give preliminary results of the total well length.²⁵ The length (L_C) to satisfy the cooling loads can be expressed as follows:

$$L_C = \frac{q_a R_{ga} + (q_{lc} - 3.41 W_c)(R_b + PLF_m R_{gm} + R_{gd} F_{sc})}{t_g - \frac{t_{wi} + t_{wo}}{2} - t_p} \quad (5)$$

More information about the above parameters can be obtained from the ASHRAE (2017) online Handbook – HVAC application, Chapter 34.

Based on the data calculated above the required length of the GHX in order to satisfy the cooling loads was estimate as follows:

$L_c = 400$ m is the total length for the heat exchanger loop at 29°C.

Ground loop design software, GLD: The GLD software is a monthly, and hourly analysis program tool²⁶ which has been employed in this study in order to estimate the GHX length. The length obtained from this simulation was found to be 400 m. Furthermore, the inlet and the outlet water temperatures were 39.4°C and 45.6°C, respectively. Figure 7 shows the average entering water temperature to the GSHP unit for a 22 year period.

Despite the wide use of the ASHREA method, several studies^{27–29} have indicated that using the ASHRAE method to calculate the length of the ground heat exchanger leads to 10%~30% oversizing of the GHEs. Thus, in this simulation, the result obtained from the GLD, which was 400 m total length is used in the TRNSYS analyses.

Ground source heat pump simulation

To provide the literature with information on the use of a GSHP in a hot/dry climate, TRNSYS has been used to simulate the whole system. Similar to ASHP, a water to air heat pump, type 919 was selected. The data in the manufacturer's catalogue was used to model the ground source heat pump. The capacity

Table 5. Design input data of GHSP.

Design input data	Specification
Borehole diameter	128 mm
Pipe type	HDPE, SDR11
Pipe thermal conductivity	0.38 W/(m K)
Inside diameter	34.5 mm
Outside diameter,	42.2 mm
Fluid type	Water
Soil thermal conductivity	2.6 W/(m K)
underground temperature at 60 m depth	29°C
Prediction time	22 Years

of the pump selected was again 3 and 5 ton for heating and cooling, respectively. This is higher than the value presented in Table 3 in order to include a safety factor. The office building was modelled in TRNSYS v. 18 using the multizone building component (Type 56a).

The simulation was run for a twenty year period based on the TMY2 (typical meteorological years) data. In the TRNSYS model, the characteristics and considerations of the borehole are the same as those used in sizing the GHX in Table 5. The simulation results' emphasis is on the amount of energy conservation and liquid flow temperature that leads to the identification of the properties of the surrounding ground.

Figure 8 shows the COP for the GSHP during the simulation period, and Table 4 shows the COP and monthly power consumption during the simulation period, as well as the savings rate for both systems.

Results and discussion

Savings on the power consumption

Energy consumption is an essential factor that determines the efficiency of the system. The monthly energy consumption of the GSHP and ASHP systems are compared in detail in Table 4 and Figure 9. It is shown that in the hottest months (June - September) the power consumption using the GSHP is approximately 37% less than that from ASHP. In addition, in the winter season, the monthly consumption value of electricity remains less than the summer in the two systems, with the GSHP system reducing the electricity use by approximately 44%. Figure 10 shows the comparison of the COP for the GSHP and the ASHP.

From Table 4, it is observed that the total energy required is 11,183 kWh per year and 17,602 kWh per year for the GSHP and ASHP respectively, and the annual electricity cost is determined as follows:

$$\text{Cost per year} = \text{power (kWh)} \text{ electricity tariff} \quad (6)$$




Figure 7. Average entering water temperature to the GSHP unit for a 22 year period by the GLD.




Figure 8. COP for the GSHP unit.




Figure 9. Comparison of the power consumption for the GSHP and the ASHP.




Figure 10. Comparison of the COP for the GSHP and the ASHP.




Figure 11. Total heat rejected and extracted from/to the soil.

Saudi electricity cost: SR 0.32 per kWh
 For GSHP electricity cost = $11,183 \text{ kWh} \times \text{SR } 0.32$
 per kWh
 = SR 3,579 per year

For ASHP electricity cost = $17,602 \text{ kWh} \times \text{SR } 0.32$
 per kWh
 = SR 5,632 per year
 Annual cost saving = $5,632 - 3,579 = \text{SR } 2,053$

A total reduction of approximately 36% in the annual of electricity can be obtained by using a GSHP system. This saving does not include the cost of the power to produce the hot water that can again be produced by the GSHP. On the other hand, the energy consumption by the circulating pump is not included in the total electricity consumption.

Therefore, using the GSHP not only reduces the total power consumption but also reduces the overall CO₂ emissions. For the purposes of calculating the annual rate of the CO₂ emissions, CO₂ emission can be expressed as follows:

$$\text{CO}_2 \text{ emissions} = \text{Emissions Factor (EF)} \times \text{power Consumption kW.h} \quad (7)$$

Based on the Carbon Footprint Ltd.³⁰ the EF for Saudi Arabia is estimate as 0.7176 Kg CO₂/kW.h. As a result, from Table 4 the GSHPs saving is 6,419 kWh/year and this leads to a saving of 4,606 kg CO₂/year.

Initial cost analysis

When comparing the two air condition systems, two cost factors play a crucial role in determining the feasibility of using the new system, namely the initial cost and the life-span cost. Table 6 shows the total cost over a 22-year period and the parameters that effect the initial value for both systems.

It is important to note that the unit life-span of the GSHP is assumed to be double that of the ASHP. The typical life-span of the ASHP is 10–15 years but in harsh climates, such as Saudi Arabia, the ASHP is

Table 6. The cost analysis for the ASHP and GSHP for 22 years.

	ASHP	GSHP
GHE Loop length, m	–	400
Unit price	20,000	10,000
Drilling cost, SR	–	40,000
GHX Pipe price, SR	–	1,000
Installation GHX, SR	–	6,000
Total initial cost, SR	20,000	57,000
Maintenance/22 y	56,980	28,490
Power consumption cost, SR/y	5,632	3,579
Power consumption cost, SR/22y	$5632 \times 22 = 123,904$	$3,579 \times 22 = 78,738$
Total cost for 22 years	200,884	164,228
Total saving	18.24 %	

exposed to very high ambient temperatures, corrosion in the coastal region and dust. Due to this, the lifetime of the ASHP is assumed to be 11 years. On the other hand, the GSHP system is located indoors and is not exposed to external factors and a typical life-span is 20-25 years; thus 22 years is assumed as the lifetime of the GSHP.

Furthermore, hot water production is a positive point for GSHPs. In new and well insulated residential buildings, power consumption by hot water maybe 3.5 times higher than the heating demand.³¹ This energy demand saving by employing GSHP needs many more investigations in a hot climate and in particular as to what extent it affects the efficiency of the system.

Simple payback periods

Generally, in renewable energy systems, the high initial cost of installation of the system is usually reclaimed by energy savings. Therefore, there are several ways to evaluate the feasibilities in the investments of the new system, such as the payback period (PBP), life-cycle cost analysis (LCCA), net present value (NPV) and return on investment (ROI). Despite the fact that PBP does not consider a cost-effectiveness tool because it does not include the long-term factors. The simple payback period (7) can be expressed as follows:

$$PBP = \frac{K_2 - K_1}{(E + M)_1 - (E + M)_2} \quad (8)$$

where

- PBP = payback time, years.
- K = capital investment.
- E = annual energy cost.
- M = annual maintenance cost.
- 1 = system under consideration (ASHP).
- 2 = alternative system (GSHP).

The annual maintenance cost, M , is given by:

$$M = \frac{0.5 \times K}{\text{year of life cycle}} \quad (9)$$

$$M_2 = (0.5 \times 57,000) \div 22 = SR1,295$$

where we have assumed that the maintenance cost for the ASHP M_1 is double that of the M_2 . Thus $M_1 = 2590$. From Table 6, equation (9) becomes:

$$PBP = \frac{57,000 - 20,000}{(5,632 + 2590)_1 - (3,579 + 1,295)_2}$$

$$PBP = 11 \text{ years.}$$

Underground thermal imbalance

The thermal imbalance is considered one of the most challenging elements that can be calculated due to a large number of factors related to the operating conditions such as climatic conditions and the length of each season in the year, the time and duration of the system operation, soil characteristics and type of system. In hot dry climate regions, as is clear from figure 11, GSHP operates in the cooling mode most of the time and this causes heat accumulation in the soil (more heat is rejected into the soil more than is extracted) this may lead to a system failure in the long run.³² In cold regions, Tian et al.,³³ discussed the most critical factors that lead to thermal imbalance and ways to reduce its impact, such as increasing the area of the well, increasing the depth of the well and improving the soil properties. For that, the thermal imbalance should be taken into account in the initial stages in the design to avoid system failure or low efficiency. The imbalance ratio (IR) is defined as follows:

$$IR = \frac{Q_{inj} - Q_{ext}}{\max(Q_{inj}, Q_{ext})} \times 100\% \quad (10)$$

<

where Q_{inj} is the accumulated heat rejected to the soil in the cooling seasons and Q_{ext} is the accumulated heat extracted from the soil in the heating seasons.

To determine the accumulated heat for the GSHP, the average COP for the GSHP is determined from Figure 8 to be 4.1 based on the TRNSYS simulation and from equation (3) the EER = 13 . From Table 3 the ground load is determined as follows:

$$\text{Cooling load, } Q_C = 14 \text{ kW/h} \times 3,412.142 = 47,768 \text{ Btu/h}$$

$$\text{Heating load, } Q_h = 10 \text{ kW/h} \times 3,412.142 = 34,120 \text{ Btu/h}$$

In the cooling mode, the condenser rejects heat to the ground heat exchanger, and the evaporator extracts heat from the load. The heat rejected at the condenser is given by

$$\begin{aligned} Q_{cond} &= Q_c ((\text{EER} + 3.412)/\text{EER}) \\ &= 47,768 \text{ Btu/h} \times ((13 + 3.412)/13) \\ &= 60,305 \text{ Btu/h} \end{aligned}$$

The heat extracted at the evaporator is given by

$$\begin{aligned} Q_{evap} &= Q_h \times (\text{COP} - 1)/\text{COP} = 34,120 \\ &\times (4.1 - 1)/4.1 = 25,798 \text{ Btu/h} \end{aligned}$$

Thus, the thermal imbalance ratio is given by

$$\text{IR} = \frac{25,798 - 60,305}{60,305} \times 100\% = -57\%$$

In contrast, the monthly-accumulated heat obtained from TRNSYS is presented in Table 7.

From Table 7, it is observed that the total accumulated heat rejected to the soil is 37,094 kWh compared to 4,148 kWh extracted from the soil in the heating seasons, and based on equation (10) the imbalance ratio (IR) is defined as follows:

$$\text{IR} = \frac{4,148 - 37,094}{37,094} \times 100\% = -88.8\%$$

The negative IR indicates that the heat transfer to the soil is more than the heat extraction, which normally occurs in cooling dominated situations, and such a high IR rate must be taken into account to maintain the efficiency of the system. In addition, a lower IR means a smaller difference between the heating and cooling loads.

Discussion of the results of this Saudi Arabia application

In this work, TRNSYS software has been used to provide a fully comprehensive simulation for the ASHP and GSHP in terms of the operating efficiency. Despite the simulation results showing that the GSHP is applicable for hot and dry climate regions, the lack of accurate data on the main governing parameters

Table 7. Monthly accumulated heat to the soil.

Month	Monthly accumulated heat	
	Heating	Cooling
Jan	1,963	–
Feb	814	81
Mar	297	393
Apr	–	2,760
May	–	5,228
Jun	–	6,067
Jul	–	7,032
Aug	–	7,131
Sep	–	5,097
Oct	–	2,839
Nov	158	439
Dec	917	27
Overall	4,148	37,094

may affect, negatively or positively, the efficiency and therefore performance of a real system. The study has a number of limitations, for example, the lack of information on the groundwater and soil layers, which have different thermal conductivity. In particular, it has been assumed that there is only one soil layer and no groundwater effects. These could significantly increase or decrease the GHX size and thus lead to a major effect on the initial system cost. In addition, domestic hot water produced by the GSHP is not considered in this analysis.

On considering the long term running of the system, the results of the study have shown that the rate of the simulation of the underground thermal imbalance is approximately 88% compared to 66% theoretically. This could be due to the effect of the parameters considered, such as the thermal conductivity, underground temperature, soil humidity, liquid flow and pipe diameter. In addition, the function and type of the building will have an effect on the thermal imbalance and the GSHP performance. For example, when a school building is closed in the summer, this will lead to a reduction in the heat entering to the soil. Likewise, health clubs with swimming pools can use the GSHPs to heat the water and maintain a thermal balance.

In addition, the geological characteristics present in one region will be different in another region, for example aquifers. When the velocity of groundwater exists, the rate of heat transfer increases and thus, the length of the GHX decreases, which has an impact on the initial and operational cost.³⁴

Moreover, when comparing the results obtained from this study with several studies that have been performed in MENA countries, all of them showed similar trends which illustrate the possibility of benefiting from the GSHP systems. For instance, the results performed by Karamallah et al.³⁵ in the city of Baghdad in Iraq, concluded that the COP of the GSHP was 2.6, which is acceptable, but lower than the result found in this study. This difference

could be due to the depth of the borehole, namely only 7.5 m which is very short for vertical GSHP systems. Likewise, in Jordan,³⁶ which is a northern border state to Saudi Arabia, 5 * 60 kW GSHP is installed and connected to 32 double boreholes with 71 m depth in order to cover the heating, cooling and hot water demand for buildings with a total area of 6000 square meters. In this project, the thermal conductivity and ground temperature were found to be 1.98 W/m-K and 19.4 °C, respectively, compared to 2.6 W/m-K and 29 °C in this study. The average COP for heating and cooling was 5, which is higher than the 4.1 predicted in this study. This is due to the lower soil and ambient temperature in Jordan. However, the underground thermal imbalance was not investigated.

Finally, there is a lack of accurate information on the price of GSHP in the Saudi market, which makes it difficult to make a comparison between the unit cost. Therefore, the use of a simple value for the pay-back period requires much more care.

Even though there are, as described above, a large number of estimates and approximations in the analysis, the use of the industry standard software, TRNSYS gives credibility to this work. It also supports, using far better modelling techniques, the initial work by the authors on this subject.¹⁰ This all reinforces that basic point of this work, that the implementation of GSHP is a far more viable approach, both in terms of primary energy and cost that the ASHP system currently, universally employed in the Middle East. It is particularly important to note, that much of the wealth of Saudi Arabia is based on drilling holes for energy extraction. It would be advantageous for this expertise to be used to save energy for drilling vertical loops for GSHP systems.

Conclusion and future work

Conclusion

In this paper, for the first time, the more accurate and industrial standard TRNSYS has been used in an annual simulation of the GSHP system compared to the ASHP system in a hot and dry climate. The COP, EER and Initial cost were investigated. The ASHRAE method and the GLD software were used to determine the length of the GHX from the results detailed above the following can be drawn:

- The soil thermal conductivity is high with an average 2.6 W/(m.K). in contrast; the underground temperature is high, and this leads to a reduction in the GSHP efficiency
- The total cost savings over a 22 year period were found to be 18%.
- The thermal imbalance ratio was 88.5%.
- The payback period exceeds 11 years when compared to the ASHP system.

- Despite the higher underground temperature, the inlet and outlet fluid temperatures remaining in the design range for most manufacturing companies.
- Despite these positive results of the GSHP efficiency, the high rate of the underground thermal imbalance (88%) could lead to a system failure in the long term.

Adding to the studies conducted in different climatic regions; this work fulfils the knowledge gap of performance and examines, using accurate modeling techniques the feasibility of GSHP in a hot dry climate when the very high soil temperature acts as a negative effect and the high thermal conductivity of the ground as a positive effect.

Future work

More research is required to fully identify the thermal imbalance and the best way to reduce the high level of cumulative heat in the ground. In addition, a comprehensive method is required to better estimate the feasibilities of the investments such as the life-cycle cost analysis.

It is also suggested that the impact of the government's adoption of a new policy for using renewable energy technology, namely by subsidizing and encouraging residents to use alternative energy conservation methods, such as solar, wind and geothermal energy, is considered. This will make the approach proposed by the authors even more valuable to denizens of the Kingdom.

Acknowledgments

The authors would like to acknowledge the scholarship from the Ministry of Education in Saudi Arabia to undertake this research work.

Declaration of Conflicting Interests

The author(s) declared no potential conflicts of interest with respect to the research, authorship, and/or publication of this article.

Funding

The author(s) received no financial support for the research, authorship, and/or publication of this article.

ORCID iD

Faisal Alshehri  <https://orcid.org/0000-0002-1201-5168>

References

1. Ding Y, Chai Q, Ma G, et al. Experimental study of an improved air source heat pump. *Energy Convers Manag* 2004; 45: 2393–2403.
2. Michopoulos A, Voulgari V, Tsikaloudaki A, et al. Evaluation of ground source heat pump systems for residential buildings in warm Mediterranean regions: the example of Cyprus. *Energy Effic* 2016; 9: 1421–1436.

3. Vakiloroyaya V, Samali B, Fakhar A, et al. A review of different strategies for HVAC energy saving. *Energy Convers Manag* 2014; 77: 738–754.
4. Naili N, Hazami M, Attar I, et al. In-field performance analysis of ground source cooling system with horizontal ground heat exchanger in Tunisia. *Energy* 2013; 61: 319–331.
5. Serageldin A, Abdelrahman A and Ookawara S. Earth-Air heat exchanger thermal performance in Egyptian conditions: experimental results, mathematical model, and computational fluid dynamics simulation. *Energy Convers Manag* 2016; 122: 25–38.
6. Belatrache D, Bentouba S and Bourouis M. Numerical analysis of earth air heat exchangers at operating conditions in arid climates. *Int J Hydrogen Energy* 2017; 42: 8898–8904.
7. Tambe V. *Feasibility study of ground coupled heat pump systems for small office building types in Phoenix, Arizona*. Master Thesis, Arizona State University, USA, 2014.
8. Healy P and Ugursal V. Performance and economic feasibility of ground source heat pumps in cold climate. *Int J Energy Res* 1997; 21: 857–870.
9. Christodoulides P, Aresti L and Florides G. Air-conditioning of a typical house in moderate climates with ground source heat pumps and cost comparison with air source heat pumps. *Appl Therm Eng* 2019; 158: 113772.
10. Al Sabawi K. First geothermal system in Palestine. In: *ECEEE 2009 summer study on energy efficiency: innovative buildings technologies*, vol. 7, France, 2009, pp.1493–1498. La Colle Sur Loup: Stockholm.
11. Yasin B and Alkhalwaldeh A. Ground source heat pump systems and pump exchanger systems in Jordan. In: *CESARE_17 : COORDINATING ENGINEERING FOR SUSTAINABILITY AND RESILIENCE*, Dead Sea, Jordan, 3–8 May 2017. Jordan University of Science and Technology: Irbid, Jordan.
12. Zhou Z, Zhang Z, Chen G, et al. Feasibility of ground coupled heat pumps in office buildings: a China study. *Appl Energy* 2016; 162: 266–277.
13. Alshehri F, Beck S, Ingham D, et al. Techno-economic analysis of ground and air source heat pumps in hot dry climates. *J Build Eng* 2019; 26: 100825.
14. Persson T, Mazzetti M, Røkke P, et al. Software for modelling and simulation of ground source heating and cooling systems. Report, SINTEF Energy Research, Trondheim Norway, May 2016.
15. GmbH T. TRANSOLAR Software, www.trnsys.de/docs/trnsys3d/trnsys3d_uebersicht_de.htm (accessed 27 January 2019).
16. SBC:2018. Saudi Building Code, www.sbc.gov.sa/En/BuildingCode/Pages/SBC_2018.aspx (accessed 27 July 2018).
17. Alrashed F and Asif M. Analysis of critical climate related factors for the application of zero-energy homes in Saudi Arabia. *Renewable Sustainable Energy Rev* 2015; 41: 1395–1403.
18. Khanlari A, Sözen A, Sahin B, et al. Experimental investigation on using building shower drain water as a heat source for heat pump systems. *Energy Sources, Part A* 2020; 1–13.
19. Afshari F. Experimental and numerical investigation on thermoelectric coolers for comparing air-to-water to air-to-air refrigerators. *J Therm Anal Calorim* 2020. DOI: 10.1007/s10973-020-09500-6
20. Johnson Controls. R-410A ZE/XN SERIES, www.upgnet.com/PdfFileRedirect/5190086-YTG-D-0118.PDF (2014, accessed 10 July 2019).
21. Said S, Habib M, Mokheimer E, et al. Feasibility of using ground-coupled condensers in A/C systems. *Geothermics* 2010; 39: 201–204.
22. Gettings M. Heat-flow measurements at shot points along the 1978 Saudi Arabian seismic deep-refraction line. Report, Geological Survey, USA, Report no. 82-794, 1982.
23. Florides G and Kalogirou S. Annual ground temperature measurements at various depths. In: *CLIMA conference*, Lausanne, Switzerland, 9–12 October 2005, paper no. 112s.
24. Thermal Dynamics. GLD Software geothermal HVAC software design package, www.groundloopdesign.com/ (accessed 5 June 2018).
25. Kavanaugh S and Rafferty K. *Geothermal heating and cooling: Design of ground-source heat pump*. Atlanta: ASHRAE, 2014.
26. Mensah K, Jang Y and Choi J. Assessment of design strategies in a ground source heat pump system. *Energy Build* 2017; 138: 301–308.
27. Ruan W and Horton W. Literature review on the calculation of vertical ground heat exchangers for geothermal heat pump systems. In: *International high performance buildings conference*, Purdue, USA, 12–15 July 2010, paper no. 45, pp. 3463, 1–5. Purdue: Purdue University.
28. Cullin J, Spittler J, Montagud C, et al. Validation of vertical ground heat exchanger design methodologies. *Sci Technol Built* 2015; 21: 137–149.
29. Staiti M and Angelotti A. Design of borehole heat exchangers for ground source heat pumps: a comparison between two methods. *Energy Procedia* 2015; 78: 1147–1152.
30. Carbon Footprint Ltd. 2020 Grid electricity emissions factors. Report for the Carbon Footprint Ltd. Basingstoke Hampshire, UK, June 2020.
31. Bagdanavicius A and Jenkins N. Power requirements of ground source heat pumps in a residential area. *Appl Energy* 2013; 102: 591–600.
32. Wu W, Wang B, You T, et al. A potential solution for thermal imbalance of ground source heat pump systems in cold regions: ground source absorption heat pump. *Renew Energy* 2013; 59: 39–48.
33. You T, Wu W, Shi W, et al. An overview of the problems and solutions of soil thermal imbalance of ground-coupled heat pumps in cold regions. *Appl Energy* 2016; 177: 515–536.
34. Capozza A, De Carli M and Zarrella A. Investigations on the influence of aquifers on the ground temperature in ground-source heat pump operation. *Appl Energy* 2013; 107: 350–363.
35. Abd Karamallah A, Hussen H and Hoshi H. Experimental model of ground-source heat pump system. In: *The 7th Jordanian international mechanical engineering conference*, Amman, Jordan, 27–29 September 2010.
36. Ayadi O, Abdalla N, Alranyes S, et al. Green renovation of the Higher Council of Science and Technology building in Jordan, www.jeaconf.org/UploadedFiles/Document/1691972b-8971-477f-b587-e36b009ba2e5.pdf (accessed 17 November 2020).

Appendix

Notation

AEFLH	annual equivalent full load hours	Q_{out}	heat supplied or removed by the system
ASHP	air source heat pumps	Q_{inj}	the accumulated heat rejected to the soil
COP	coefficient of performance	Q_{ext}	the accumulated heat extracted from the soil
D	depth below the surface (m)	Q_C	cooling load, Btu/h
EER	energy efficiency ratio	Q_h	heating load, Btu/h
EF	emissions Factor (kg CO ₂ /year)	Q_{cond}	the heat rejected at the condenser, Btu/h
GHX	ground heat exchanger	Q_{evap}	the heat extracted at the evaporator, Btu/h
GLD	ground loop design software	T_{mean}	mean surface temperature, °C
GSHP	ground source heat pumps	TMY2	typical meteorological years
IR	the imbalance ratio	$T_{soil(D,year)}$	soil temperature at a depth D, °C
LCCA	life-cycle cost analysis	U-value	thermal transmittance
L_c	borehole length for the cooling loads (m)	W_{in}	the work required by the system
MENA	the Middle East and North Africa	α	thermal diffusivity of the ground
NPV	net present value		
PBP	payback period		