



Deposited via The University of Sheffield.

White Rose Research Online URL for this paper:

<https://eprints.whiterose.ac.uk/id/eprint/74693/>

Monograph:

Owens, D.H. and Chu, B. (2009) Modelling the influence of non-minimum phase zeros on gradient based linear iterative learning control. Research Report. ACSE Research Report no. 991 . Automatic Control and Systems Engineering, University of Sheffield

Reuse

Items deposited in White Rose Research Online are protected by copyright, with all rights reserved unless indicated otherwise. They may be downloaded and/or printed for private study, or other acts as permitted by national copyright laws. The publisher or other rights holders may allow further reproduction and re-use of the full text version. This is indicated by the licence information on the White Rose Research Online record for the item.

Takedown

If you consider content in White Rose Research Online to be in breach of UK law, please notify us by emailing eprints@whiterose.ac.uk including the URL of the record and the reason for the withdrawal request.

Modelling the Influence of Non-minimum Phase Zeros on Gradient based Linear Iterative Learning Control

David H Owens, Bing Chu

Department of Automatic Control and Systems Engineering,

University of Sheffield,


Mappin Street, Sheffield, S1 3JD, UK

Eric Rogers, Chris T Freeman, Paul L Lewin

School of Electronics and Computer Science,

University of Southampton,

Southampton SO17 1BJ, UK



Research Report No. 991

Department of Automatic Control and Systems Engineering

The University of Sheffield

Mappin Street, Sheffield,

S1 3JD, UK

May 2009

Modeling the Influence of Non-minimum Phase Zeros on Gradient based Linear Iterative Learning Control

David H Owens, Bing Chu

Department of Automatic Control and Systems Engineering, University of Sheffield, Mappin Street, Sheffield S1 3JD, UK

Eric Rogers, Chris T Freeman, Paul L Lewin

School of Electronics and Computer Science, University of Southampton, Southampton SO17 1BJ, UK

Abstract

The subject of this paper is modeling of the influence of non-minimum phase plant dynamics on the performance possible from gradient based norm optimal iterative learning control algorithms. It is established that performance in the presence of right-half plane plant zeros typically has two phases. These consist of an initial fast monotonic reduction of the L_2 error norm followed by a very slow asymptotic convergence. Although the norm of the tracking error does eventually converge to zero, the practical implications over finite trials is apparent convergence to a non-zero error. The source of this slow convergence is identified and a model of this behavior as a (set of) linear constraint(s) is developed. This is shown to provide a good prediction of the magnitude of error norm where slow convergence begins. Formulae for this norm are obtained for single-input single-output systems with several right half plane zeroes using Lagrangian techniques and experimental results are given that confirm the practical validity of the analysis.

Key words: non-minimum phase plants, iterative learning control, optimization.

Email addresses: d.h.owens@shef.ac.uk (David H Owens, Bing Chu),
etar@ecs.soton.ac.uk (Eric Rogers, Chris T Freeman, Paul L Lewin).

1 Introduction

Iterative learning control (ILC) is a technique for controlling systems operating in a repetitive (termed trial-to-trial, iteration-to-iteration or pass-to-pass) mode with the requirement that a reference trajectory $r(t)$ defined over a finite interval (trial or pass length) $0 \leq t \leq \alpha$ is followed to a high precision. Examples of such systems include robotic manipulators that are required to repeat a given task to high levels of accuracy, chemical batch processes or, more generally, the class of tracking systems.

Since the original work [1] in the mid 1980s, the general area of ILC has been the subject of intense research effort. An initial source for the literature here are the survey papers [2], [3] and [7]. A key point here is that many linear model based algorithms have also seen experimental benchmarking.

One class of widely considered algorithms (e.g. [5] and [6]) are “gradient based” i.e. iterate to produce the desirable property of reducing error norm magnitudes from trial-to-trial. One wide class of such algorithms using both function and parameter optimization methods is reviewed in [7]. As in all control algorithms, including the familiar feedback control paradigm, there are limitations as to what ILC can achieve depending on the characteristics of the plant. In particular, the structural properties of the plant are critical to what can be achieved. This paper, motivated by results first given in [4], uses standard tools from functional analysis in a Hilbert space to investigate the effects of non-minimum phase zeros on the convergence behavior of gradient based algorithms using the so-called norm optimal ILC (NOILC) approach [5]. This algorithm has the property of guaranteeing, for a wide class of linear systems, convergence of tracking errors to zero (in norm) but has been observed to exhibit a slow convergence behaviors for non-minimum-phase systems. The aim of the analysis in this paper is to provide a model of this observed behavior with a view to predicting its main parameters. The validity of the theoretical results in predicting observed phenomena is verified by experimental results obtained from an electro-mechanical testbed.

2 Background

Definition 1 *Consider a dynamic system with input u and output y . Let \mathcal{Y} and \mathcal{U} be the output and input function spaces respectively and let $r \in \mathcal{Y}$ be a desired reference trajectory for the system. An ILC algorithm is successful if, and only if, it constructs a sequence of control inputs $\{u_k\}_{k \geq 0}$ which, when applied to the system (under identical experimental conditions), produces an*

output sequence $\{y_k\}_{k \geq 0}$ with the following properties of convergent learning

$$\lim_{k \rightarrow \infty} y_k = r, \quad \lim_{k \rightarrow \infty} u_k = u_\infty \in \mathcal{U}$$

Here convergence is interpreted in terms of the topologies assumed in \mathcal{Y} and \mathcal{U} respectively.

Note that this general description of the problem allows a simultaneous description of linear and nonlinear dynamics, continuous or discrete plant with either time-invariant or time varying dynamics.

Let the space of output signals \mathcal{Y} be a real Hilbert space and \mathcal{U} also be a real (and possibly distinct) Hilbert space of input signals. The respective inner products (denoted by $\langle \cdot, \cdot \rangle$) and norms $\|\cdot\|^2 = \langle \cdot, \cdot \rangle$ are indexed in a way that reflects the space if it is appropriate to the discussion e.g. $\|x\|_{\mathcal{Y}}$ denotes the norm of $x \in \mathcal{Y}$.

The dynamics of the systems considered here are assumed to be linear and represented in operator form as

$$y = Gu + d$$

where $G : \mathcal{U} \rightarrow \mathcal{Y}$ is the system input/output operator (assumed to be bounded and typically a convolution operator) and d is a term describing initial condition or other trial independent effects such as disturbances. If $r \in \mathcal{Y}$ is the reference trajectory or desired output then the tracking error is defined as

$$e = r - y = r - Gu - d$$

This paper considers the NOILC algorithm of [5] which, on completion of trial k , calculates the control input signal on trial $k + 1$ as the solution of the minimum norm optimization problem

$$u_{k+1} = \arg \min_{u_{k+1}} \{J_{k+1}(u_{k+1}) : e_{k+1} = r - y_{k+1}, y_{k+1} = Gu_{k+1} + d\}$$

where the performance index, or optimality criterion, is

$$J_{k+1}(u_{k+1}) = \|e_{k+1}\|_{\mathcal{Y}}^2 + \|u_{k+1} - u_k\|_{\mathcal{U}}^2 \quad (1)$$

The initial control $u_0 \in \mathcal{U}$ can be arbitrary in theory but, in practice, will be a good first guess at the solution of the problem.

This problem can be interpreted as the determination of a sequence of control inputs with the properties that, on trial $k + 1$, (i) the tracking error is reduced in an optimal way; and (ii) this new control input does not deviate too much from the control input used on trial k . The relative weighting/importance of these two objectives can be absorbed into the definitions of the norms in \mathcal{Y} and \mathcal{U} . The control input on trial $k + 1$ is obtained from the stationarity condition, necessary for a minimum, by Fréchet differentiation of (1) with respect to u_{k+1} as

$$u_{k+1} = u_k + G^* e_{k+1}, \quad \forall k \geq 0 \quad (2)$$

where G^* is the adjoint operator for G . This leads easily, using $y = Gu + d$ and $e = r - y$, to the following formulae for the change in error from trial-to-trial

$$e_{k+1} - e_k = -GG^* e_{k+1}, \quad \forall k \geq 0 \quad (3)$$

and hence

$$e_{k+1} = (I + GG^*)^{-1} e_k, \quad u_{k+1} = u_k + G^*(I + GG^*)^{-1} e_k, \quad \forall k \geq 0 \quad (4)$$

Now consider the special case of a differential linear time-invariant plant modeled by the state-space triple $\{A, B, C\}$ operating over a time interval $[0, \alpha]$ (with state, input and output $y(t)$, $x(t)$, and $u(t)$ respectively). In this case, with input and output spaces being $L_2[0, \alpha]$ spaces with appropriate norms, G is defined by the equation

$$(Gu)(t) = C \int_0^t e^{A(t-\tau)} Bu(\tau) d\tau, \quad d(t) = Ce^{At}x(0) \quad (5)$$

and the cost function takes the form

$$J_{k+1} = \int_0^\alpha \{e_{k+1}^T(t) Q e_{k+1}(t) + (u_{k+1}(t) - u_k(t))^T R (u_{k+1}(t) - u_k(t))\} dt \quad (6)$$

where the weighting matrices Q and R are symmetric positive definite.

The adjoint operator G^* in the solution (2) is often an anti-causal operator but in the case of (5) it can be converted into a causal algorithm [5] using familiar Riccati methods. The route is to consider the cost function as a variation of the linear quadratic regulator problem and, in particular, as a problem of combined tracking (of $r(t)$) and disturbance accommodation (regarding $u_k(t)$)

as a known disturbance on trial $k + 1$). If we assume full knowledge of the state vector, the optimal input on trial $k + 1$ is then

$$u_{k+1}(t) = u_k(t) - R^{-1}B^T[K(t)x_{k+1}(t) - \xi_{k+1}(t)] \quad (7)$$

where the feedback gain matrix $K(t)$ satisfies the Riccati differential equation

$$\begin{aligned} \dot{K}(t) &= -A^TK(t) - K(t)A + K(t)BR^{-1}B^TK(t) - C^TQC \\ K(\alpha) &= 0 \end{aligned} \quad (8)$$

and the predictive or feedforward term $\xi_{k+1}(t)$ is generated by

$$\dot{\xi}_{k+1}(t) = -\left(A - BR^{-1}B^TK(t)\right)^T \xi_{k+1}(t) - \zeta C^TQ e_k(t)$$

with terminal condition

$$\xi_{k+1}(\alpha) = 0$$

The predictive term in this algorithm driven by a combination of the tracking error and the input on the previous trial k and also the reference signal. This is therefore a causal ILC algorithm consisting of current trial full state feedback combined with feedforward from the previous trial output tracking error data. This representation of the solution is causal in the ILC sense because the costate system can be solved off-line, between trials, by reverse time simulation using available previous trial data. The differential matrix Riccati equation for the feedback matrix $K(t)$ needs to be solved only once before the sequence of trials begin. Also by reducing R to infinitesimally small values, high gain state feedback can be achieved which generates, intuitively, maximum convergence rates whilst satisfying the stability constraint. This is in contrast to high gain output feedback which cannot be used in practice due to instabilities arising from right-half plane zeros.

Norm optimal ILC has been shown ([5]) to have the following convergence properties for the error sequence $\{e_k\}$ and input sequence $\{u_k\}$:

- (1) The change in input $u_{k+1} - u_k$ converges in norm to zero.
- (2) If the input $\{u_k\}$ converges, the limit is the input that minimizes the error norm $\|r - Gu - d\|^2$ (where for ease of notation we have omitted explicit mention of the underlying function space(s)).
- (3) The error sequence generated by (1) is monotonically decreasing in norm.
- (4) The error norm converges monotonically to zero if the reference signal is in the range of the plant or arbitrarily close to it.

The algorithm [5] is hence universally convergent and universally applicable in theory and is known to be capable of excellent convergence properties. This has been seen in extensive simulation work and, most importantly, in experimental benchmarking on a gantry robot [11] and experimental applications including an accelerator based free electron laser [12]. Both applications are minimum-phase. Non-minimum phase properties are the subject of this paper which also provides experimental verification of these results using a non-minimum-phase electro-mechanical system.

For a simple simulation example, Figure 1 shows the results of applying this ILC algorithm to the minimum-phase plant

$$G(s) = \frac{s + 1}{(s + 2)(s + 3)}$$

with $r(t) = 5 \sin(\frac{\pi}{2}t)$ and in the cost function $Q = 20$, and $R = 1$. The good convergence behavior is clearly visible with several orders of magnitude reductions in J (and hence error norm) in the first 10 trials before convergence rates reduce.




Fig. 1. NOILC performance from a typical minimum phase system: a) error, e_k , b) cost function, J_k , c) control input, u_k and d) output, y_k .

Convergence can, however, be associated with poor performance when the plant is non-minimum phase. More precisely, if the plant is non-minimum phase convergence to zero is still guaranteed but the convergence behavior is very different. For example, Figure 2 shows, with the same reference signal and cost function weighting as Figure 1, the convergence behavior for the transfer-function above with the numerator polynomial replaced by $s - 1$. From this data, the algorithm is seen to reduce errors rapidly in the first few trials but then “stagnates”, moving along a “plateau” of almost constant error norm

with only very small changes from trial-to-trial. For all practical purposes, (i) the input after the 6th trial barely changes and hence (ii) the error appears to be converging to a non-zero value. The problem is that the non-zero error “achieved” is, in this case, only an improvement of a factor of approximately 10 in norm over the initial error norm, an entirely unsatisfactory outcome. The task undertaken by this paper is to explain why this is happening and to model the behavior with the intention of predicting the stagnated values and signals.




Fig. 2. Non-minimum phase example with apparent convergence to a non-zero, large error: a) error, e_k , b) cost function, J_k , c) control input, u_k and d) output, y_k .

In the analysis which follows, attention is focussed primarily on the case of single-input single-output systems with m right half-plane zeros $\{z_j : \mathcal{R}e(z_j) > 0, 1 \leq j \leq m\}$. It will be shown that the NOILC algorithm exhibits two different convergence rates characterized by factoring the space of all possible error signals into two subspaces. One of these is associated with the span of functions generated by the signals $e^{-z_j t}, 1 \leq j \leq m$. This subspace will be denoted here by \mathcal{E}_+ and will be seen to be associated with slow convergence if the trial length $[0, \alpha]$ is “long”. The other subspace is taken to be its orthogonal complement \mathcal{E}_+^\perp . The desired input producing zero error normally has components in both subspaces. The rate of convergence of the error will be seen to be different for these two subspaces where, in particular, the convergence rate is much higher for components of error signals in \mathcal{E}_+^\perp than those in \mathcal{E}_+ .

3 Characterization of \mathcal{E}_+

Suppose that G has m right-half plane zeros described by the list $\{z_j : 1 \leq j \leq m_0\}$ with z_j having multiplicity n_j and $\sum_{j=1}^{m_0} n_j = m$. The analysis is

initiated by consideration of the action of the operator GG^* on the signals

$$\theta_{ji}(t) = \frac{1}{(i-1)!} t^{i-1} e^{-z_j t} = \mathcal{L}^{-1} \left[\frac{1}{(s+z_j)^i} \right], \quad 1 \leq i \leq n_j, 1 \leq j \leq m_0 \quad (9)$$

In this case

$$\mathcal{E}_+ = \text{span}\{\theta_{ji} : 1 \leq i \leq n_j, 1 \leq j \leq m_0\}, \quad \dim(\mathcal{E}_+) = m \quad (10)$$

In the generic case of $n_j = 1, \forall j$, these functions have the notationally simpler form

$$\theta_j(t) = e^{-z_j t} = \mathcal{L}^{-1} \left[\frac{1}{(s+z_j)} \right], \quad 1 \leq j \leq m \quad (11)$$

and this case

$$\mathcal{E}_+ = \text{span}\{\theta_j : 1 \leq j \leq m\}, \quad \dim(\mathcal{E}_+) = m \quad (12)$$

The zeros can be real or complex. In the complex case the function θ_{ji} and its complex conjugate are replaced by the real and imaginary parts. The details are omitted for brevity.

In what follows, it is necessary to have an explicit representation of G^* when the input and output vector spaces are $L_2(0, \alpha)$ Hilbert spaces with inner products

$$\langle u_1, u_2 \rangle_{\mathcal{U}} = \int_0^{\alpha} u_1^T(t) R u_2(t) dt, \quad \langle y_1, y_2 \rangle_{\mathcal{Y}} = \int_0^{\alpha} y_1^T(t) Q y_2(t) dt \quad (13)$$

The following theorem (which applies also to multi-input multi-output systems) follows from the definitions

Theorem 1 *With the above definitions, the adjoint operator of the linear map $y = Gu$ corresponding to the linear, time-invariant state space model $S(A, B, C, D)$*

$$\dot{x}(t) = Ax(t) + Bu(t), \quad y(t) = Cx(t) + Du(t), \quad x(0) = 0 \quad (14)$$

is the map $v = G^*z$ corresponding to the linear system

$$\dot{p}(t) = -A^T p(t) - C^T Q z(t), \quad v(t) = R^{-1}(B^T p(t) + D^T z(t)) \quad (15)$$

with a terminal boundary condition $p(\alpha) = 0$.

For the purposes of this paper, the case of single-input, single-output (SISO) systems will be considered. In this case, the identity $QR^{-1}C(sI + A)^{-1}B \equiv R^{-1}B^T(sI + A^T)^{-1}C^TQ$ proves that $v = G^*z$ also has the realization

$$\dot{p}(t) = -Ap(t) - Bz(t), \quad v(t) = QR^{-1}(Cp(t) + Dz(t)), \quad p(\alpha) = 0 \quad (16)$$

Using the notation $\tilde{f}(t) \equiv f(\alpha - t)$ to denote the time reversed signal, it is a simple matter to show that $\|f\| = \|\tilde{f}\|$ and, for SISO systems,

$$v = G^*z \quad \Leftrightarrow \quad \tilde{v} = QR^{-1}G\tilde{z} \quad (17)$$

i.e. (in a similar manner to the discrete time gradient methods [6]) the response of G^* to the input z is just QR^{-1} times the time reversal of the response of G to the time reversed z . This observation will be used in the following analysis.

The next step is the analysis of asymptotic behaviors of $G^*\theta_{ji}$ and $GG^*\theta_{ji}$ as $\alpha \rightarrow \infty$. More precisely, the following theorem can be proved:

Theorem 2 *Assume only simple zeros of multiplicity $n_j = 1$. With the above definitions and constructions and assuming that the operator G is an asymptotically stable SISO system with transfer function $G(s)$, then*

$$(G^*\theta_j)(t) = e^{-z_j\alpha}QR^{-1}(\tilde{y}_{z_j})(t), \quad 1 \leq j \leq m \quad (18)$$

where y_{z_j} is defined as the response of the plant G from zero initial conditions to the input signal $e^{z_j t}$ i.e.

$$y_{z_j}(t) = \mathcal{L}^{-1} \left[G(s) \frac{1}{s - z_j} \right] \quad (19)$$

As a consequence,

$$\lim_{\alpha \rightarrow \infty} \|G^*\theta_j\| = 0, \quad \lim_{\alpha \rightarrow \infty} \|GG^*\theta_j\| = 0, \quad 1 \leq j \leq m \quad (20)$$

It is important to note the following.

- (1) The result applies for complex zeros where the appropriate θ_j functions are taken as the real and imaginary parts of $e^{-z_j t}$.
- (2) The result also applies to multiple non-minimum phase zeros with the function $\{\theta_j\}$ replaced by the set $\{\theta_{ji}\}$ in a natural way. The proof of this is similar to the above and is omitted for brevity.

Proof: The proof follows from the equation

$$(G^*\theta)(t) = QR^{-1}[\widetilde{G\tilde{\theta}}](t) = QR^{-1}e^{-z_j\alpha}\tilde{y}_{z_j}(t) \quad (21)$$

so that

$$\|G^*\theta\| = QR^{-1}\|\widetilde{G\tilde{\theta}}\| = QR^{-1}e^{-z_j\alpha}\|\tilde{y}_{z_j}\| = QR^{-1}e^{-z_j\alpha}\|y_{z_j}\| \quad (22)$$

and, in a similar way,

$$\|GG^*\theta\| = QR^{-1}e^{-z_j\alpha}\|G\tilde{y}_{z_j}\| \leq QR^{-1}\|G\|_{L_2[0,\alpha]}e^{-z_j\alpha}\|y_{z_j}\| \quad (23)$$

and is completed by the observation that

$$\sup_{\alpha>0}\|y_{z_j}\|_{L_2[0,\alpha]} < \infty \quad \& \quad \sup_{\alpha>0}\|G\|_{L_2[0,\alpha]} < \infty \quad (24)$$

(as G is asymptotically stable) and $Re[z_j] > 0$ (by definition). \square

It is important to interpret this theorem in terms of its implications for algorithm performance when G is non-minimum phase. In norm optimal ILC, the change in error is just $e_{k+1} - e_k = -GG^*e_{k+1}$. The theorem hence states clearly that, when the time interval α is large in the sense that all non-minimum phase zeros satisfy $\alpha z_j \gg 1$, the change in error due to the component of e_{k+1} in the subspace \mathcal{E}_+ spanned by $\theta_j, 1 \leq j \leq m$ is extremely small. As a consequence, the error norm sequence $\{\|e_{k+1}\|\}_{k \geq 0}$, although monotonic, will ultimately "plateau" out in the way seen in the examples of Section 2 and the experimental results seen in Section 5.

The theorem can be summarized in the form

$$\lim_{\alpha \rightarrow \infty} \|GG^*\theta\| = 0 \quad \Leftrightarrow \quad \theta \in \mathcal{E}_+ \quad (25)$$

i.e. $\theta \in \mathcal{E}_+$ is sufficient to produce the required observed property. In what follows, the following (unproven) hypothesis will be assumed to be true.

The m -dimensional subspace \mathcal{E}_+ spanned by the functions θ_j defined above is both necessary and sufficient to describe the slow convergence behavior. That is,

$$\lim_{\alpha \rightarrow \infty} \|GG^*\theta\| = 0 \quad \Leftrightarrow \quad \theta \in \mathcal{E}_+ \quad (26)$$

Evidence to support the truth of this hypothesis has been seen in many simulations and is also implied by the success of the experimental results later in

this paper. It can also be supported by examining the response of GG^* to the signal $f(t) = e^{-zt}$ where z is any complex number with strictly positive real part. Similar calculations to those used in the proof of the theorem then yield the formula

$$(GG^*f)(t) = f_0(t) + G(z)e^{-zt}, \quad \lim_{\alpha \rightarrow \infty} e^{z\alpha} \|f_0\| < \infty \quad (27)$$

which does not vanish as $\alpha \rightarrow \infty$ unless z is equal to one of the z_j . That is the right-half plane zeros of G are the only values of z with the desired property.

4 Modeling Slow Algorithm Convergence using Linear Constraints

The analysis and interpretation of the previous section can be used to motivate the construction of an approximate mathematical model of the slow convergence behavior of NOILC for a non-minimum phase system G under the assumption that the time interval $[0, \alpha]$ is long enough (or, more precisely, $z_j\alpha \gg 1$ for $1 \leq j \leq m$). Details are given below.

To construct the approximate model, use the identity $e_{k+1} - e_k = -GG^*e_{k+1}$ and write the error signal space as $\mathcal{E}_+ \oplus \mathcal{E}_+^\perp$ where \mathcal{E}_+^\perp is the orthogonal complement of \mathcal{E}_+ . The choice of \mathcal{E}_+^\perp as a complement to \mathcal{E}_+ is a crucial construction for what follows and is motivated by the fact that GG^* is self adjoint and maps elements of \mathcal{E}_+ into points arbitrarily close to $\{0\}$. This can be interpreted as suggesting that \mathcal{E}_+ is "almost a kernel of GG^* " and hence "almost invariant". As a consequence it is concluded that $e_{k+1} - e_k$ evolves predominantly in the subspace \mathcal{E}_+^\perp .

Note: To provide additional support for this construction, suppose that a bounded linear operator H is such that HH^* has finite dimensional (and hence closed) kernel S (i.e. it maps S "exactly" into the point set $\{0\}$), then it is easily proved that $HH^*S^\perp \subset S^\perp$. More precisely, let $y \in S^\perp$ be arbitrary and write $HH^*y = z + z^\perp$ with $z \in S$ and $z^\perp \in S^\perp$. Let $x \in S$ be arbitrary and note that $\langle x, HH^*y \rangle = \langle HH^*x, y \rangle = \langle x, z \rangle = 0 \quad \forall x \in S$. It follows that $z = 0$ and hence $HH^*S^\perp \subset S^\perp$ as stated.

Motivated by the above and assuming that, to a good approximation, and for the purposes of our calculations, $GG^*\mathcal{E}_+^\perp \subset \mathcal{E}_+^\perp$, then the error sequence satisfies the following linear constraint(s) for a large number of iterations

$$\langle e_{k+1} - e_k, \theta \rangle = 0, \quad \forall \theta \in \mathcal{E}_+, \quad \alpha \gg 0 \quad (28)$$

This can be rewritten as the set of linear constraints

$$\langle e_{k+1} - e_k, \theta_j \rangle = 0, \quad 1 \leq j \leq m \quad (29)$$

or, as $e_{k+1} - e_k = -G(u_{k+1} - u_k)$, as

$$u_{k+1} \in \Omega_{k+1} = \{u : \langle u - u_k, \psi_j \rangle = 0, 1 \leq j \leq m\}, \quad \psi_j = G^* \theta_j \quad (30)$$

The introduction of these linear constraints as described is the mechanism used below to construct the proposed model of algorithm evolution introduced in this paper to explain and predict the behavior of NOILC applied to plants with open right-half plane zeros. The implications of this are analyzed below.

Note: the approximation will break down as iterations progress as, ultimately, the error does go to zero but the model is proposed as a good approximation over initial and possibly large number of trials where the plateau/stagnation effect is seen in practice.

Proposed Model: *The model of NOILC behavior when applied to a non-minimum phase system is that the signal u_{k+1} computed from NOILC can be approximated by the solution of the constrained optimization problem*

$$u_{k+1} = \arg \min \{J_{k+1} = \|e_{k+1}\|^2 + \|u_{k+1} - u_k\|^2 : u_{k+1} \in \Omega_{k+1}\} \quad (31)$$

and that the limit, as $k \rightarrow \infty$, of these solutions provides a good approximation to behavior on the plateau.

Next the solution to this optimization problem is approached using Lagrange multiplier techniques i.e. by minimizing the Lagrangian

$$J_{k+1}^\lambda = \frac{1}{2} J_{k+1} + \sum_{j=1}^m \lambda_j \langle \psi_j, u_{k+1} - u_k \rangle \quad (32)$$

over all $u_{k+1} \in \mathcal{U}$ (the change in input) and all scalars λ_j (the Lagrange multipliers). The necessary condition for a minimum is that J_{k+1}^λ is stationary at the optimal u_{k+1} and $\lambda = [\lambda_1, \lambda_2, \dots, \lambda_m]^T$.

Note: The addition of these constraints retains all properties of the NOILC algorithm except that the error sequence $\{e_k\}_{k \geq 0}$ does not necessarily converge to zero.

The solution of this problem is stated in the following theorem which uses the notation P_ϵ to denote the self-adjoint, orthogonal projection operator onto the

span of m linearly independent vectors $\epsilon_1, \dots, \epsilon_m$. In more detail,

$$P_\epsilon x = [\epsilon_1, \epsilon_2, \dots, \epsilon_m] M_\epsilon^{-1} \beta_\epsilon(x) \quad (33)$$

where M_ϵ is the symmetric, positive definite (and hence nonsingular) $m \times m$ matrix with (i, j) element $\langle \epsilon_i, \epsilon_j \rangle$ and $\beta_\epsilon(x)$ is the $m \times 1$ vector with i th element $\langle \epsilon_i, x \rangle$.

Theorem 3 *With the above construction, suppose that G is injective. Then the solution of the constrained Norm Optimal ILC algorithm on the $(k+1)^{th}$ iteration takes the form*

$$u_{k+1} - u_k = (I - P_\psi) G^* e_{k+1} \quad (34)$$

and has the monotonicity property

$$\|e_{k+1}\| \leq \|e_k\| \quad \forall k \geq 0 \quad (35)$$

In addition, if e_k converges to e_∞ (in the norm topology), then it can be computed from the formulae

$$e_\infty = \sum_{j=1}^m \gamma_j \theta_j, \quad \gamma = [\gamma_1, \dots, \gamma_m]^T = M_\theta^{-1} \beta_\theta(e_0) \quad (36)$$

and the limiting norm is just

$$\|e_\infty\|^2 = \beta_\theta(e_0)^T M_\theta^{-1} \beta_\theta(e_0) \quad (37)$$

Proof: Firstly note that the choice $u = u_k$ is suboptimal and the monotonicity property is easily proved. Next, the conditions for a stationary point of the Lagrangian consists of the constraint equations and, taking the Fréchet derivative with respect to u_{k+1} , the equalities

$$u_{k+1} - u_k = G^* e_{k+1} - \sum_{j=1}^m \lambda_j \psi_j$$

Taking the inner product with ψ_i and using the constraints,

$$0 = \langle \psi_i, G^* e_{k+1} \rangle - \sum_{j=1}^m \lambda_j \langle \psi_i, \psi_j \rangle, \quad 1 \leq i \leq m$$

which is just $0 = \beta_\psi(G^*e_{k+1}) - M_\psi\lambda$. It follows that

$$u_{k+1} - u_k = G^*e_{k+1} - \sum_{j=1}^m \lambda_j \psi_j = (I - P_\psi)G^*e_{k+1} \quad (38)$$

Now operate with G to give $e_{k+1} - e_k = -G(I - P_\psi)G^*e_{k+1}$. Assuming that $e_k \rightarrow e_\infty$ then gives $0 = G(I - P_\psi)G^*e_\infty$ or, as G is injective,

$$G^*e_\infty = P_\psi G^*e_\infty \in \text{span}\{\psi_j\}_{1 \leq j \leq m} \quad (39)$$

Write $P_\psi G^*e_\infty = \sum_{j=1}^m \gamma_j \psi_j = G^* \sum_{j=1}^m \gamma_j \theta_j$ and note that G being injective implies that G^* is injective. It follows that

$$e_\infty = \sum_{j=1}^m \gamma_j \theta_j \quad (40)$$

It is trivially true that $e_\infty = P_\theta e_\infty$ where P_θ is the orthogonal projection onto the m -dimensional subspace spanned by $\{\theta_j\}_{1 \leq j \leq m}$. It follows therefore that

$$\gamma = [\gamma_1, \dots, \gamma_m]^T = M_\theta^{-1} \beta_\theta(e_\infty) \quad (41)$$

The result follows if it is proved that $\beta_\theta(e_\infty) = \beta_\theta(e_0)$. To do this rewrite the constraints $\langle u_{k+1} - u_k, \psi_j \rangle = 0, 1 \leq j \leq m, k \geq 0$, in the form $\langle e_{k+1} - e_k, \theta_j \rangle = 0, 1 \leq j \leq m, k \geq 0$. This is just $\langle e_{k+1} - e_0, \theta_j \rangle = 0, 1 \leq j \leq m, k \geq 0$. Taking the limit, the conclusion now follows from $\langle e_\infty, \theta_j \rangle = \langle e_0, \theta_j \rangle, 1 \leq j \leq m$ and the definition of $\beta_\theta(e)$.

Finally, the norm $\|e_\infty\|^2$ is computed from

$$\langle e_\infty, e_\infty \rangle = \langle [\theta_1, \dots, \theta_m] M_\theta^{-1} \beta_\theta(e_0), [\theta_1, \dots, \theta_m] M_\theta^{-1} \beta_\theta(e_0) \rangle$$

which gives

$$\|e_\infty\|^2 = (M_\theta^{-1} \beta_\theta(e_0))^T M_\theta (M_\theta^{-1} \beta_\theta(e_0)) = \beta_\theta(e_0)^T M_\theta^{-1} \beta_\theta(e_0) \quad (42)$$

This completes the proof of the theorem. \square

The theorem is a precise description of properties of the proposed constrained NOILC model. In what follows, these ideas are interpreted in terms of anticipated performance of the “real” NOILC algorithm.

Summary and Interpretation of the Results: For a single-input single output, stable non-minimum phase system with zeroes $z_j, 1 \leq j \leq m$, in the right-half

plane and $z_j\alpha \gg 0, 1 \leq j \leq m$, convergence takes the form of initial reductions in error norm in \mathcal{E}_+^\perp followed by a “plateau” where error norms in \mathcal{E}_+ reduce infinitesimally from trial-to-trial. The chosen model of the effect of these zeroes as linear equality constraints on the dynamics of NOILC characterizes and predicts the error e_∞ on the plateau component as follows

$$e_\infty = \sum_{j=1}^m \gamma_j \theta_j, \quad \gamma = [\gamma_1, \dots, \gamma_m]^T = M_\theta^{-1} \beta_\theta(e_0) \quad (43)$$

and the value of error norm along the plateau using

$$\|e_\infty\|^2 = \beta_\theta(e_0)^T M_\theta^{-1} \beta_\theta(e_0) \quad (44)$$

Note: In the case when the plant has only one right-half plane zero z the equations simplify to produce

$$e_\infty = e^{-zt} \frac{2z}{1 - e^{-2z\alpha}} \int_0^\alpha e^{-zt} e_0(t) dt, \quad \|e_\infty\|^2 = \frac{2z}{1 - e^{-2z\alpha}} \left[\int_0^\alpha e^{-zt} e_0(t) dt \right]^2$$

which shows more clearly the interaction between the basis function e^{-zt} and the initial error e_0 . Note also that the experimental system used in the next section has this property

The above can be used to complete this section. More precisely, it is noted that the error seen on the plateau is small only when $\beta_\theta(e_0)$ is small. This can be achieved under two conditions only:

- (1) The initial tracking error signal e_0 is small in norm or, more generally,
- (2) the quantities $\langle \theta_j, e_0 \rangle, 1 \leq j \leq m$ are all small, which can be true if e_0 is not small but is small in some time interval $[0, \alpha_0] \subset [0, \alpha]$ with $Re[z_j]\alpha_0 \gg 1, 1 \leq j \leq m$. This could be achieved naturally if, for example, the plant has zero initial conditions and the reference r is zero in $[0, \alpha_0]$. Choosing $u_0(t)$ to be zero in this interval achieves the objective with no effort.

5 Application to a Physical Example

Application of ILC to experimental systems is an important part of the development and evaluation of the subject area and a number of results are available as in [8], [11] and [12]. It is also clearly necessary to test the practical value and robustness of these results in physical experiments where, inevitably, the

transfer function used in analysis is only an approximation to the actual plant dynamics. Here the (rotary) electro-mechanical, non-minimum phase test facility shown in Figure 3 is used to assess the validity of the methods and results of this paper.




Fig. 3. Experimental Setup.




Fig. 4. Non-minimum phase characteristic.

The experimental test-bed has previously (see, for example, [10]) been used to evaluate a number of ILC schemes and consists of a rotary mechanical system of inertias, dampers, torsional springs, a timing belt, pulleys and gears.

The non-minimum phase characteristic is achieved by using the arrangement shown in Figure 4 where θ_i and θ_o are the input and output positions, J_r and J_g are inertias, B_r is a damper, K_r is a spring and G_r represents the gearing. A further spring-mass-damper system is connected to the input in order to increase the relative degree and complexity of the system. Frequency response test measurements have been used to obtain continuous-time plant transfer-function (including a proportional plus integral plus derivative stabilizer)

$$G(s) = \frac{165.95(4 - s)}{s^4 + 21.5s^3 + 170.28s^2 + 368.52s + 663.82} \quad (45)$$

This system is non-minimum phase with one zero at $s = 4$ (giving $z = 4$) in the right-half of the complex plane. The one dimensional subspace \mathcal{E}_+ is

hence spanned by the single vector e^{-4t} . Choosing a time interval $t \in [0, 6]$, the factor $\alpha z = 4 \times 6 = 24$ so $e^{-\alpha z} = e^{-24}$ is extremely small suggesting that the theoretical results of this paper should apply with good accuracy.

To show the close agreement existing between predicted and measured results, 40 trials of NOILC, using cost function weights $Q = 5$, and $R = 1$, and a sampling frequency of 250Hz, have been performed, using the reference, $r(t)$, shown in Figure 5d). The reference comprises a sinusoidal positional movement (in radians), which is both preceded and followed by periods where it is set at zero. Following the discussion under (1) and (2) at the end of Section 4, there exists a time interval for this case $[0, 1.5] \subset [0, 6]$ where the reference r is zero and the plant has zero initial conditions. Hence the error e_0 will be zero in this interval leading to a low predicted final error, e_∞ , and associated norm $\|e_\infty\|$. These predicted values are shown in Figure 5a) and b) respectively, and accurately match the experimental results obtained.




Fig. 5. Experimental results with initial zero period: a) error, e_k , b) error norm, $\|e_k\|$, c) control input, u_k and d) output, y_k

In order to examine a case where a significant non-zero final error is predicted, the reference is now replaced with that shown in Figure 6d). This corresponds to the same movement as the previous reference, however the starting point has now been changed to half way along its length. The initial period of $r(t)$ is now not zero so, recalling again the discussion under (1) and (2) at the end of Section 4, the e_0 will *not* be small in this interval, leading to predicted error values significantly different from zero, as shown in Figure 6 a) and b). Again, 40 trials of NOILC, using cost function weights $Q = 5$, and $R = 1$, have been performed, and the experimental error results, e_k and $\|e_k\|$ obtained can be seen to closely match their predicted counterparts e_∞ and $\|e_\infty\|$. In particular, the error norm $\|e_k\|$ enters the plateau at $\|e_k\| \approx 2$ (plot b) in Figure 6) and

the predicted error is modeled by $e_\infty \approx 6e^{-4t}$ (plot a) in Figure 6).




Fig. 6. Experimental results without initial zero period: a) error, e_k , b) error norm, $\|e_k\|$, c) control input, u_k and d) output, y_k

6 Conclusions

The paper has modeled observed behavior of norm optimal iterative learning control when the plant has a number of open right-half plane zeros. This observed behavior consists of two phases of convergence. The first occurs in the first few iterations where the algorithm normally exhibits good (and potentially rapid) error norm reductions. The second phase then sets in and exhibits extremely slow reductions, typically so slow that, to all practical intents and purposes, the algorithm is not converging. The plot of $\|e_k\|$ against k appears to "plateau" at a constant value that represents the best experimental accuracy that can be achieved.

This phenomenon has been explained by proving that the self-adjoint plant operator GG^* almost annihilates well-defined signals associated with the zeros e.g. one such signal for a zero z is e^{-zt} . The span of these signals is an m -dimensional subspace \mathcal{E}_+ of the output signal space where convergence is inevitably slow. In contrast, convergence of the component in the orthogonal complement \mathcal{E}_+^\perp can be rapid.

The analysis has been used to motivate a model of the phenomenon. More precisely, it has been proposed that the NOILC algorithm is behaving as if it is subject to m equality constraints (orthogonality conditions). This model is used to predict the values of error and error norm associated with the plateau

using Lagrangian methods. The model provides some insight into the effects of initial error e_0 and reference signal on the algorithm behavior and suggests that a small initial error and/or a reference signal with an initial period of inactivity are simple practical ways of improving performance and accuracy. Finally the predictions of the model have been shown to be good in practice using an electro-mechanical benchmarking experiment.

Further work is needed to generalize the ideas to the case of multi-input multi-output systems (where the same phenomenon occurs).

References

- [1] Arimoto, S., Kawamura, S. & Miyazaki, F., *Bettering operations of robots by learning*, 1984, Journal of Robotic Systems, 1, pp. 123–140.
- [2] Bristow, D. A., Tharayil, M., & Alleyne, A. G., *A survey of iterative learning control*, IEEE Control Systems Magazine, 2006, 26(3), pp. 96–114.
- [3] Ahn, H.-S., Chen, Y., and Moore, K. L., *Iterative learning control: brief survey and categorization*, 2007, IEEE Transactions on Systems, Man and Cybernetics, Part. C, 37(6), pp. 1109–1121.
- [4] N. Amann & D. H. Owens *Non-minimum phase plants in iterative learning control*, Proc International Conference on Intelligent Systems Engineering, IEE Conf Publication No 395, pp. 107–112, 1994.
- [5] Amann, N., Owens, D. H. & Rogers, E., *Iterative learning control using optimal feedback and feedforward actions*, 1996, International Journal of Control, 65(2), pp. 277–293.
- [6] Owens, D. H., Hatonen, J.J. & Daley S., *Robust monotone gradient-based discrete-time iterative learning control*, 2008, International Journal of Robust and Nonlinear Control, 19, pp. 634–661.
- [7] Owens, D. H. & Hatonen, *Iterative learning control - An optimization paradigm*, 2005, IFAC Annual reviews in Control, 29, pp. 57–70.
- [8] Daley, S., Owens, D. H. & Hatonen, J, *Application of optimal iterative learning control to the dynamic testing of structures*, 2007, Special Issue of the Proceedings of the Institution of Mechanical Engineers, Part I (special issue on "Dynamic Testing), 221, pp. 211–222.
- [9] Kwakernakk, H. & Sivan, R. Kwakernaak, H., Sivan, R., *Linear Optimal Control Systems*, Willey, New York, 1972.
- [10] Cai, Z., Freeman, C. T., Lewin, P. L., & Rogers, E., *Iterative learning control for a non-minimum phase plant based on a reference shift algorithm*, 2006, Control Engineering Practice, 16(6), pp. 633–643.

- [11] Ratcliffe, J.D., Lewin, P. L., Rogers, E., Hatonen J.J. & Owens, D.H., *Norm-optimal iterative learning control applied to gantry robots for automation applications*, 2006, IEEE Transactions on Robotics, 22(6), pp. 1303–1307.
- [12] Kirchhoff, S., Schmidt, C., Lichtenberg, G. & Werner, H., *An iterative learning algorithm for control of an accelerator based free electron laser*, 2008, Proceeding of the 47th IEEE Conference on Decision and Control, Cancun, Mexico, Dec 9-11, pp. 3032–3037.