



Contents lists available at ScienceDirect

## Data in Brief

journal homepage: [www.elsevier.com/locate/dib](http://www.elsevier.com/locate/dib)



### Data Article

# Data on the natural ventilation performance of windcatcher with anti-short-circuit device (ASCD)



Payam Nejat<sup>a,\*</sup>, John Kaiser Calautit<sup>b</sup>,  
Muhd Zaimi Abd. Majid<sup>c</sup>, Ben Richard Hughes<sup>b</sup>,  
Fatemeh Jomehzadeh<sup>a,d</sup>

<sup>a</sup> Faculty of Civil Engineering, Universiti Teknologi Malaysia, UTM, Skudai, Johor, Malaysia

<sup>b</sup> Department of Mechanical Engineering, University of Sheffield, Sheffield, UK

<sup>c</sup> Construction Research Center, Institute of Smart Infrastructure and Innovative Construction, Universiti Teknologi Malaysia, Johor, Malaysia

<sup>d</sup> Advanced Built and Environment Research (ABER) center, Tehran, Iran

### ARTICLE INFO

#### Article history:

Received 18 May 2016

Received in revised form

6 August 2016

Accepted 20 August 2016

Available online 28 August 2016

### ABSTRACT

This article presents the datasets which were the results of the study explained in the research paper 'Anti-short-circuit device: a new solution for short-circuiting in windcatcher and improvement of natural ventilation performance' (P. Nejat, J.K. Calautit, M.Z. Abd. Majid, B.R. Hughes, F. Jomehzadeh, 2016) [1] which introduces a new technique to reduce or prevent short-circuiting in a two-sided windcatcher and also lowers the indoor CO<sub>2</sub> concentration and improve the ventilation distribution. Here, we provide details of the numerical modeling set-up and data collection method to facilitate reproducibility. The datasets includes indoor airflow, ventilation rates and CO<sub>2</sub> concentration data at several points in the flow field. The CAD geometry of the windcatcher models are also included.

© 2016 Published by Elsevier Inc. This is an open access article under the CC BY license (<http://creativecommons.org/licenses/by/4.0/>).

### Specifications Table

Subject area *Environmental Science*

DOI of original article: <http://dx.doi.org/10.1016/j.buildenv.2016.05.023>

\* Corresponding author.

E-mail addresses: [payam.nejaat@gmail.com](mailto:payam.nejaat@gmail.com) (P. Nejat), [J.Calautit@sheffield.ac.uk](mailto:J.Calautit@sheffield.ac.uk) (J.K. Calautit).

<http://dx.doi.org/10.1016/j.dib.2016.08.042>

2352-3409/© 2016 Published by Elsevier Inc. This is an open access article under the CC BY license (<http://creativecommons.org/licenses/by/4.0/>).

More specific subject area	<i>Air quality, Building, Natural ventilation, Simulation</i>
Type of data	<i>Graphs, tables, geometry</i>
How data was acquired	<i>ANSYS FLUENT</i>
Data format	<i>Raw, analysed</i>
Experimental factors	<i>The computational domain was sized based on best practice guideline COST 732. Lateral and vertical extension of the domain was 5H (5 times the height of the building). For the extension of the domain in the direction of flow, 5H used for inlet. For the outlet, the boundary was positioned 15H behind the building. Atmospheric boundary layer (ABL) approach flow profile were imposed on the inlet of the domain. For carbon dioxide concentration simulation, simplified exhalation model [8] was used.</i>
Experimental features	<i>The CFD code ANSYS FLUENT was used to solve the governing equations (continuity, momentum and energy) in the computational domain using the finite volume method. The second-order upwind scheme was used for numerical discretization along with SIMPLE algorithm. The standard k-<math>\epsilon</math> turbulence model was used.</i>
Data source location	<i>UK</i>
Data accessibility	<i>Data of current article</i>

---

## Value of the data

- The computational data can be used to verify modeling predictions of the ventilation rates, airflow and CO<sub>2</sub> concentration distributions in buildings with a windcatcher.
  - The data can be used for comparing with the results of other's simulation model by providing a benchmark.
  - It can be used for CFD user training and improvement of the accuracy of numerical simulations of windcatchers.
  - It can be employed to assess various design optimization of the windcatcher and anti-short-circuit device.
- 

## 1. Data

This article presents the supply and exhaust rates of a windcatcher with “anti-short-circuit device (ASCD)” and also the indoor airflow and carbon dioxide concentration data at several points in the test room incorporating [1]. Four two-sided windcatcher designs were used: benchmark windcatcher, windcatcher with 30° ASCD, windcatcher with 60° ASCD and windcatcher with 90° ASCD. To save time and effort, the geometry files are also attached in [Supplementary 2](#).

The supplementary file includes the following data:

**Air short-circuit data** ([Supplementary Table 1](#)) – This dataset provides values of the airflow velocity (Y- direction) obtained from the plotted points between the supply and exhaust channels below the windcatcher for various ASCD angles.

**Ventilation rates data** ([Supplementary Table 2](#)) – This dataset provides values of airflow velocity obtained from the plotted points inside the supply channel of the windcatcher for various ASCD angles.

**Airflow distribution data** ([Supplementary Table 3](#)) – This dataset provides values of airflow velocity obtained from the plotted points inside the test room for various ASCD angles.




Fig. 1. Surface mesh of the windcatcher and room model.





Fig. 2. Convergence monitoring of continuity, velocity,  $k$  and epsilon.

**Carbon dioxide concentration data** (Supplementary Table 4) – This dataset provides values of  $\text{CO}_2$  concentration obtained from the plotted points inside the test room for various ASCD angles.

**CAD Geometry files** (Supplementary 2) – The dataset provides CAD geometry files of four configurations of the two-sided windcatcher: standard windcatcher, windcatcher with  $30^\circ$  ASCD, windcatcher with  $60^\circ$  ASCD and windcatcher with  $90^\circ$  ASCD. The windcatcher is integrated to a test room which is surrounded by macro (outdoor) domain.

## 2. Experimental design, materials and methods

A discretized Computational Fluid Dynamics (CFD) code ANSYS FLUENT was used to solve the governing equations (continuity, momentum and energy) in the computational domain using the finite volume method. The second-order upwind scheme was used for numerical discretization along



**Fig. 3.** Measurement points for the (a) airflow short-circuiting, (b) CO<sub>2</sub> concentration and airflow distribution.

with SIMPLE algorithm. The standard *k-ε* turbulence model was used, which is a well-established method in simulations of natural ventilation such as windcatchers [2–7]. The computational domain consisted of a single fluid zone combining the indoor and outdoor. For meshing the domain, unstructured mesh techniques was used. The domain was sized based on best practice guideline COST 732. Lateral and vertical extension of the domain was 5H (5 times the height of the building). For the extension of the domain in the direction of flow, the inlet boundary was positioned 5H windward of the building. For the outlet, the boundary was positioned 15H behind the building. Atmospheric boundary layer (ABL) approach flow profile which obeyed a power-law with  $\alpha=0.25$  were imposed on the inlet of the domain. Pressure outlet was set as atmospheric. The top and side walls were set as symmetry. For carbon dioxide concentration simulation, a simplified exhalation model [8] was used. The total number of grid was approximately 8 million elements (Fig. 1). For the calculations, the computer used 12 CPUs and 16GB of memory. The simulations were completed when additional iterations did not show further variations in the monitored data (Fig. 2). Data were obtained by plotting points inside the windcatcher for the ventilation rates and test room for airflow short-circuiting (sc1–sc6, see Fig. 3a), CO<sub>2</sub> concentration and airflow distribution (p1–p9, see Fig. 3b).

## Acknowledgments

The publication fee of this paper was funded by grant Flag ship UTM QJ130000.2409.03G18.

## Transparency document. Supplementary material

Transparency data associated with this article can be found in the online version at <http://dx.doi.org/10.1016/j.dib.2016.08.042>.

## Appendix A. Supporting information

Supplementary data associated with this article can be found in the online version at <http://dx.doi.org/10.1016/j.dib.2016.08.042>.

## References

- [1] P. Nejat, J.K. Calautit, M.Z. Abd. Majid, B.R. Hughes, F. Jomehzadeh, Anti-short-circuit device: a new solution for short-circuiting in windcatcher and improvement of natural ventilation performance, *Build. Environ.* 105 (2016) 24–39. <http://dx.doi.org/10.1016/j.buildenv.2016.05.023>.
- [2] P. Nejat, J.K. Calautit, M.Z. Abd. Majid, B.R. Hughes, I. Zeynali, F. Jomehzadeh, Evaluation of a two-sided windcatcher integrated with wing wall (as a new design) and comparison with a conventional windcatcher, *Energy Build.* 126 (2016) 287–300. <http://dx.doi.org/10.1016/j.enbuild.2016.05.025>.
- [3] B.R. Hughes, J.K. Calautit, S.A. Ghani, The development of commercial wind towers for natural ventilation: a review, *Appl. Energy* 92 (2012) 606–627. <http://dx.doi.org/10.1016/j.apenergy.2011.11.066>.
- [4] J.K. Calautit, B.R. Hughes, H.N. Chaudhry, S.A. Ghani, CFD analysis of a heat transfer device integrated wind tower system for hot and dry climate, *Appl. Energy* 112 (2013) 576–591. <http://dx.doi.org/10.1016/j.apenergy.2013.01.021>.
- [5] J.K. Calautit, D. O'Connor, B.R. Hughes, Determining the optimum spacing and arrangement for commercial wind towers for ventilation performance, *Build. Environ.* 82 (2014), 274–287, <http://dx.doi.org/10.1016/j.buildenv.2014.08.024>.
- [6] J.K. Calautit, B.R. Hughes, Measurement and prediction of the indoor airflow in a room ventilated with a commercial wind tower, *Energy Build.* 84 (2014) 367–377. <http://dx.doi.org/10.1016/j.enbuild.2014.08.015>.
- [7] J.K. Calautit, B.R. Hughes, Wind tunnel and CFD study of the natural ventilation performance of a commercial multi-directional wind tower, *Build. Environ.* 80 (2014) 71–83. <http://dx.doi.org/10.1016/j.buildenv.2014.05.022>.
- [8] A. Bulińska, Z. Popiołek, Z. Buliński, Experimentally validated CFD analysis on sampling region determination of average indoor carbon dioxide concentration in occupied space, *Build. Environ.* 72 (2014) 319–331. <http://dx.doi.org/10.1016/j.buildenv.2013.11.001>.