White Rose Research Online

eprints@whiterose.ac.uk
https://eprints.whiterose.ac.uk
Universities of Leeds, Sheffield and York

Deposited via The University of Sheffield.

White Rose Research Online URL for this paper:
https://eprints.whiterose.ac.uk/id/eprint/184649/

Version: Supplemental Material

Article:
Peng, Z., Garner, B. and Stovin, V. (2022) Two green roof detention models applied in two green roof systems. Journal of Hydrologic Engineering, 27 (2). 04021049. ISSN: 1084-0699

https://doi.org/10.1061/(asce)he.1943-5584.0002155

This material may be downloaded for personal use only. Any other use requires prior permission of the American Society of Civil Engineers. This material may be found at https://doi.org/10.1061/(ASCE)HE.1943-5584.0002155

Reuse
Items deposited in White Rose Research Online are protected by copyright, with all rights reserved unless indicated otherwise. They may be downloaded and/or printed for private study, or other acts as permitted by national copyright laws. The publisher or other rights holders may allow further reproduction and re-use of the full text version. This is indicated by the licence information on the White Rose Research Online record for the item.

Takedown
If you consider content in White Rose Research Online to be in breach of UK law, please notify us by emailing eprints@whiterose.ac.uk including the URL of the record and the reason for the withdrawal request.

Table 1. Value of parameters for the two-stage physically-based (2SPB) model.

	Parameter	Conventional Green Roof	Innovative Green Roof
System configuration	Length	5 m	6.1 m
	System slope	2%	2%
Substrate layer	θ_s	0.552[a]	0.513[b]
	θ_r	0.042[a]	0.119[b]
	α_1	0.304[a]	0.108[b]
	n_1	2.820[a]	2.344[b]
	α_2	5.094E-04[a]	0.002b
	n_1	1.926[a]	2.834[b]
	w_1	0.622[a]	0.579[b]
	K_s	166.4 mm/min[a]	14.7 mm/min[b]
	θ_1	0.23[a]	-
	θ_2	0.33[a]	-
	γ_1	-1.5495[a]	-
	γ_2	-10.33[a]	-
	γ_3	-23.339[a]	-
	β_1	5.019[a]	-
	β_2	31.66[a]	-
	β_3	88.2267[a]	-
	Initial moisture content (θ_{FC})	0.33[a]	0.38[b]
	Depth	100 mm	50 mm
Drainage/detention layer	Manning's n	**0.0012[b]**	**0.017[b]**
	Initial water storage	0	0

[a] Values for MCS substrate, as proposed in Peng et al. (2020).
[b] Values from independent material characterisation tests described in this paper.

Table 2. Value of parameters for the SWMM green roof LID control (SWMM-GR) model.

	Parameter	Conventional Green Roof	Innovative Green Roof
System Configuration	W_1	1 m	1.1 m
	A_1	5 m^2	6.71 m^2
	S_1	0.02	0.02
Surface layer	$\emptyset_1$	0	0
	D_1	0	0
	n_s	0.1	0.1
	φ_2	50	50
Substrate layer	K_s	166.4 mm/min[a]	14.7 mm/min[b]
	D_2	100 mm	50 mm
	Soil wilting point	0.01	0.01
	$\emptyset_2$	0.552[a]	0.513[b]
	θ_{FC}	0.34[a]	0.38[b]
	HCO	20[b]	25.59[b]
	Initial substrate saturation	64.10%	72.55%
Drainage/detention layer	n_3	**0.0578[b]**	**0.952[b]**
	$\emptyset_3$	0.5	0.5
	D_3	25 mm	55 mm
	Initial water storage	0	0

[a] Values for MCS substrate, as proposed in Peng et al. (2020).
[b] Values from independent material characterisation tests described in this paper.

Table 3. Identified Manning's n and Roughness Coefficient for the FD-25 drainage layer.

Slope	Drainage Length	Manning's n	Roughness Coefficient
2%	2 m	0.0022	0.1090
2%	5 m	0.0012	0.0578
17.60%	2 m	0.0025	0.1542
17.60%	5 m	0.0018	0.0914